

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122658
Permit No. 83333
Basin No. 137B

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73261
WELL NAME (if applicable): GH-DW-4

1. OWNER/CLIENT NAME Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480
Round Mountain, NV. 89045

DETAILED ADDRESS AT WELL LOCATION Round Mountain Mine,
Subdivision Name: _____ County: Nye

2. PLS LOCATION SE ¼ NW ¼ 33 Sec 11 (N)S 44 E
PERMIT/WAIVER NO. Order #1198 Permit 83333
Issued by Water Resources General Permit No.

Latitude _____ UTM E 496048 NAD 27
Longitude _____ UTM N 4291090 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other Flooded Rev.

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Aluvium			0	240
Black grey rock			240	610
Tan and rust rock			610	650
Grey rock			650	680
Black, grey, and rust rock			680	700
Black grey rock			700	720
Tan clay w/ gravel			720	805
2.375 Souder - slotted			760	800

9. INSTRUCTION
Depth Drilled: 805 Feet Depth Cased: 800 Feet
HOLE DIAMETER (BIT SIZE)
From _____ To _____
26 Inches 0 Feet 40 Feet
19 Inches 40 Feet 805 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
22	86.6	.375	0	40
12.75	33.37	.250	+2	800
2.375	3.65	.145	+2	800

ANNULAR MATERIALS
Sanitary Seal Yes No
 Neat Cement 0 to 435 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips 435 to 440 Pumped Poured
 Gravel Pack [> 0.2 in.] 440 to 805 Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

Date started: 23-May 20 15
Date completed: 15-Jun 20 15

7. WATER QUALITIES
Static water level: 182 Feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I.
Water Temperature: 69 ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>151</u>	<u>460</u>	<u>2</u>

PERFORATIONS:
Type of perforation: Louvered
Size of perforation: 0.125
From 460 Feet To 780 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Boat Longyear Contractor
Address 2745 California Ave., SLC, UT 84104 Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 0021976
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2486
Signed: [Signature]
By driller performing actual drilling on site or contractor
Date: 6-Jul-15