STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122663
Permit No.
Basin No. 141

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73453
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Dana Holbrook (Holbrook)
MAILING ADDRESS 412 School St Carlin NV 89822

DETAILED ADDRESS AT WELL LOCATION [redacted]
Belmont townsite
Subdivision Name: Belmont townsite County: NYE

2. PLS LOCATION ~~SE~~ SW ¼ ~~SW~~ SE ¼ 26 Sec 9 T 0 N/S 45 E
PERMIT/WAIVER NO. 1005-581-06
Issued by Water Resources *Current Parcel No.*

Latitude 38° 35 225 UTM E ☐ NAD 27
Longitude 116° 52 1673 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Granite Sand			0	3	
Granite		118	3	340	
		235			
NAD27					
38.587150°N					
116.876973°W					

Date started: 6-8, 20 15
Date completed: 6-15, 20 15

9. WELL CONSTRUCTION
Depth Drilled: 340 Feet Depth Cased: 340 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	340	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	8	.188	+18	300
6.625	10	.250	300	340

PERFORATIONS:
Type of perforation: mill slot
Size of perforation: 3 By 3/16
From [redacted] 120 Feet To [redacted] 130 Feet
From [redacted] 250 Feet To [redacted] 260 Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal	5 to 55			
☒ Neat Cement	5 to 25	☐ Pumped	☒ Poured	
☐ Cement Grout	to	☐ Pumped	☐ Poured	
☐ Concrete Grout	to	☐ Pumped	☐ Poured	
☒ Bentonite Chips	25 to 55	☐ Pumped	☒ Poured	
☐ Bentonite Grout	to	☐ Pumped	☐ Poured	
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	55 to 340	☐ Pumped	☒ Poured	
☐ Sand Pack [< 0.2 in.]	to	☐ Pumped	☐ Poured	
☐ Other, explain:	to	☐ Pumped	☐ Poured	

7. WATER QUALITIES
Static water level: 45 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 48 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
8		8

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Rosenlund Drilling L.L.C. Contractor
Address Hc 60 Box 890 Ruby Valley NV 89833 Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 0079932
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 24165
Signed: Logan Rosenlund
By driller performing actual drilling on site or contractor
Date: 6-20-15

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY
(NSPO Rev 11-12)
(O) 627