STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122669
Permit No.
Basin No. 141

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73459
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Brett Perchetti Douglas Baker
MAILING ADDRESS PO Box 792 Tonopah NV 89049

DETAILED ADDRESS AT WELL LOCATION Block 13 lot 6 Belmont NV
Subdivision Name: Belmont townsite County: NYE

2. PLS LOCATION SW ¼ NW ¼ 26 Sec 9 N 45 E
PERMIT/WAIVER NO. 15 *Issued by Water Resources* 004-574-06 *Issued by Conservation Dist.* 004-574-09

Latitude 38°35.793 UTM E ☐ NAD 27
Longitude 116°52.368 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL# ____
☐ Replacement: Original well log # ____
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Broken shale			0	160	

Nad 27
38.596613°N
116.871890°W

Date started: 6-17, 20 15
Date completed: 6-18, 20 15

7. WATER QUALITIES
Static water level: 30 Feet below land surface
Artesian Flow: ____ G.P.M. ____ P.S.I.
Water Temperature: 51 ° Fahrenheit
Water Quality: ____

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
8		8

9. WELL CONSTRUCTION
Depth Drilled: 160 Feet Depth Cased: 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.6.25	.8	.188	+18	160

PERFORATIONS:
Type of perforation: mill slot
Size of perforation: 3 By 3/16
From 140 Feet To 160 Feet
From ____ Feet To ____ Feet
From ____ Feet To ____ Feet

ANNULAR MATERIALS

☒ Sanitary Seal	0 to 100			
☒ Neat Cement	0 to 20	☐ Pumped	☒ Poured	
☐ Cement Grout	to	☐ Pumped	☐ Poured	
☐ Concrete Grout	to	☐ Pumped	☐ Poured	
☒ Bentonite Chips	20 to 100	☐ Pumped	☒ Poured	
☐ Bentonite Grout	to	☐ Pumped	☐ Poured	
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	100 to 160	☐ Pumped	☒ Poured	
☐ Sand Pack [< 0.2 in.]	to	☐ Pumped	☐ Poured	
☐ Other, explain:	to	☐ Pumped	☐ Poured	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Rosenlund Drilling LLC *Contractor*
Address Hc 60 Box 890 Ruby Valley NV 89833 *Contractor*

Nevada contractor's license number as issued by the *State Contractor's Board:* 0079932
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2465

Signed: Logan Rosenlund *By driller performing actual drilling on site or contractor*
Date: 6-20-15

RECEIVED JUN 29 2015 NEVADA STATE ENGINEER

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY
(NSPO Rev 11-12) (O) 627