STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122693
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73122
WELL NAME (If applicable):

1. OWNER/CLIENT NAME FISHER RECOVERY TRUST
MAILING ADDRESS 1320 HWY 395 N.
GARDNERVILLE, NV 89410

DETAILED ADDRESS AT WELL LOCATION 628 FRONTAGE RD
GARDNERVILLE, NV 89410
Subdivision Name: County: Douglas

2. PLS LOCATION SW ¼ SW ¼ 24 Sec 12 N/S 20 E
PERMIT/WAIVER NO. 1220-24-410-010
Issued by Water Resources Current Parcel No.

Latitude 38.8831*N UTM E ☐ NAD 27
Longitude 119.692009*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
LARGE BOULDERS				
GRANITE BOULDERS			0	45
GRANITE BOULDERS			45	112
ODSIDIAN SANDS			112	165
DG GRAVELS				
FRACTURED DG GRAVELS		X	165	190
OBSIDIAN GRAVELS		XX	190	220

Nad 27
38.8831°N
119.692009°W

Date started: 2-Jun, 20 15
Date completed: 5-Jun, 20 15

7. WATER QUALITIES
Static water level: 75 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 47° ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
25	65	3 HRS

9. INSTRUCTION
Depth Drilled: 220' Feet Depth Cased: 220' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	100	Feet
9 7/8	Inches	100	Feet	220	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	2	20
6 5/8	4.26	.216	20	220
SDR 21				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	100	☒ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	220	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: .032

From	Feet	To	Feet
180	Feet	220	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC
Contractor
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905
Signed: By driller performing actual drilling on-site or contractor
Date: 6/10/2015

RECEIVED JUL 16 2015 STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.