STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122200
Permit No.
Basin No. 141

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69048
WELL NAME (If applicable):

1. OWNER/CLIENT NAME Theodore Schuff
MAILING ADDRESS 2712 Golfside Drive
Las Vegas NV 89134-8825

DETAILED ADDRESS AT WELL LOCATION Block 16 10+B
Belmont townsite
Subdivision Name: Belmont townsite County: NYE

2. PLS LOCATION SW ¼ NW ¼ 25 Sec 9 S 45 E
PERMIT/WAIVER NO. 004-577207
Issued by Water Resources Current Parcel No.

Latitude 38° 35.668' UTM E ☐ NAD 27
Longitude 116° 52.324 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Broken up shale			0	15	
Black shale			15	245	
Broken up granite		246	245	300	
		280			
Nad 27					
38.594533°N					
116.871156°W					

Date started: 4-20, 20 15
Date completed: 4-23, 20 15

9. WELL CONSTRUCTION
Depth Drilled: 300 Feet Depth Cased: 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11 3/4	Inches	0	Feet	55	Feet
9 7/8	Inches	55	Feet	300	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	.3	SDR 17	20	300
6 5/8	.9	.250	+18	20

PERFORATIONS:
Type of perforation: Mill slot
Size of perforation: .032
From 280 Feet To 300 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal	0 to 55			
☒ Neat Cement	5 to 25	☐ Pumped	☒ Poured	
☐ Cement Grout	to	☐ Pumped	☐ Poured	
☐ Concrete Grout	to	☐ Pumped	☐ Poured	
☒ Bentonite Chips	25 to 55	☐ Pumped	☒ Poured	
☐ Bentonite Grout	to	☐ Pumped	☐ Poured	
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	55 to 300	☐ Pumped	☒ Poured	
☐ Sand Pack [< 0.2 in.]	to	☐ Pumped	☐ Poured	
☐ Other, explain:	to	☐ Pumped	☐ Poured	

7. WATER QUALITIES
Static water level: 140 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
42		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Rosenlund Drilling LLC (Contractor)
Address Hc 60 Box 890 Ruby Valley NV 89833 (Contractor)

Nevada contractor's license number as issued by the State Contractor's Board: 0079932
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2465

Signed: Sogan Rosenlund
By driller performing actual drilling on site or contractor
Date: 4-25-15

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY
(NSPO Rev 11-12) (O) 627