STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 12270
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73118
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME MARK AND THERESA MOSCOWITZ
MAILING ADDRESS 391 MT TOM ROAD
BISHOP, CA

DETAILED ADDRESS AT WELL LOCATION 2282 PIONEER TRAIL
GEONA, NV 89411
Subdivision Name: *County:* Douglas

2. PLS LOCATION SE ¼ NW ¼ 10 Sec 13 N/S 19 E
PERMIT/WAIVER NO. DOM-15-26 *Issued by Water Resources* 1319-10-211-001 *Current Parcel No.*

Latitude 39.008143*N UTM E ☐ NAD 27
Longitude 119.839128*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
BROWN CLAY			3	26
DG SANDS AND CLAY			26	110
BROW CLAY			110	135
SILTY SANDS OBSIDIAN SANDS			135	163
BROWN GUMMY CLAY			163	190
FRACTURED OBSIDIAN SANDS		XXX	190	240

Nad 27
39.008235°N
119.838115°W

Date started: 5-May , 20 15
Date completed: 11-May , 20 15

7. WATER QUALITIES
Static water level: 68 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 46 ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
30	45	3 HRS

9. CONSTRUCTION
Depth Drilled: 240' Feet Depth Cased: 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8	4.26	.216	20	240
SDR 21				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	100	☒ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	240	☐ Pumped	☐X Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: 3 X 3/32

From	Feet	To	Feet
200	Feet	240	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC
Contractor
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board*: 0055548
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 1905
Signed: *by driller performing actual drilling on site or contractor*
Date: 5/15/2015

RECEIVED MAY 28 2015 NV ENGINEERS OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.