

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68402

1. OWNER F.H. Gubler Inc ADDRESS AT WELL LOCATION top miles south of Lund, 4 miles west of Hwy 318  
 MAILING ADDRESS Po Box 245 Lund, NV 89317  
 2. LOCATION SW 1/4 SE 1/4 Sec. 22 T 10 N/S R 61 E NYE County  
 PERMIT NO. 15620 Issued by Water Resources Parcel No. 12004 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty Clay		0	12	
gravel	water	12	12.5	.5
clay		12.5	16	
gravel	water	16	18	2
clay		18	25	
gravel	water	25	26	1
clay		26	32	
gravel	water	32	47	
clay		47	55	
gravel	water	55	60	
clay		60	67	
gravel	water	67	69	
clay		69	75	
gravel	water	75	79	
clay		79	86	
gravel	water	86	88	
clay		88	100	

2015 JUL 21 AM 10:01  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 100 Feet Depth Cased 100 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
6 Inches 50 Feet 100 Feet  
 Inches Feet Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>	<u>12.9</u>	<u>.188</u>	<u>18</u>	<u>100</u>

 Perforations:  
 Type perforation mill  
 Size perforation 1/8 x 2.5" x 6 row  
 From 50 feet to 70 feet  
 From 70 feet to 80 feet  
 From 80 feet to 100 feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From        feet to        feet  
 9. WATER LEVEL  
 Static water level 8' feet below land surface  
 Artesian flow        G.P.M.        P.S.I.  
 Water temperature 54 °F Quality good

Date started May 19, 2015  
 Date completed June 27, 2015

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>50</u>	<u>2'</u>	<u>1 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Maynard Well Drilling Contractor  
 Address Po Box 64 Lund, NV 89317 Contractor  
 Nevada contractor's license number 047726 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556  
 Signed        By driller performing actual drilling on site or contractor  
 Date July 21 15