

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122754
Permit No. _____
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70830
WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME Mona McGowilly
MAILING ADDRESS 1208 Kingston Way
Gardnerville NV 89460

DETAILED ADDRESS AT WELL LOCATION 1156 Jacobsen
Subdivision Name: _____ County: Douglas

2. PLS LOCATION NE 1/4 NE 1/4 CG Sec 12 N/S 21 E
PERMIT/WAIVER NO. 122109.001.004
Issued by Water Resources Current Parcel No.

Latitude 38.55340 UTM E NAD 83
Longitude 114.35444 UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec Other

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
<u>Overburden</u>			<u>0</u>	<u>4</u>	
<u>clay - Brown</u>			<u>4</u>	<u>15</u>	
<u>Hard clay</u>			<u>15</u>	<u>34</u>	
<u>DG - SANDSTONE</u>			<u>34</u>	<u>98</u>	
<u>DG SANDS</u>			<u>98</u>	<u>152</u>	
<u>fractured DG</u>			<u>152</u>	<u>280</u>	

9. WELL CONSTRUCTION
Depth Drilled: 280 Feet Depth Cased: 280 Feet
HOLE DIAMETER (BIT SIZE)
From _____ To _____
1 1/8 Inches 0 Feet 100 Feet
9 7/8 Inches 100 Feet 280 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>12</u>	<u>20</u>
<u>6</u>	<u>4</u>	<u>SDR21 PVC</u>	<u>20</u>	<u>280</u>

PERFORATIONS:
Type of perforation: factory Screen .040
Size of perforation: .040
From 220 Feet To 280 Feet

ANNULAR MATERIALS
 Sanitary Seal _____ to _____
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout 0 to 10.1 Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips _____ to _____ Pumped Poured
 Bentonite Grout _____ to _____ Pumped Poured
 15 % 20 % Other, explain: _____
 Gravel Pack [> 0.2 in.] 10.1 to 280 Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

Date started: 3-9 , 20 14
Date completed: 3-17 , 20 14

7. WATER QUALITIES
Static water level: 120 Feet below land surface
Artesian Flow: NA G.P.M. NA P.S.I.
Water Temperature: COND ° Fahrenheit
Water Quality: clear

8. WELL TEST DATA

Test Method:	Bailer	Pump	Air Lift	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
			<input checked="" type="checkbox"/>	<u>257</u>		<u>2.5</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: Blair Drilling Contractor
Address: P.O. 1255 Reno NV 89502 Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 46498A
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2239
Signed: [Signature]
Date: 4-10-14
By driller performing actual drilling on site or contractor