STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122756
Permit No. 83692T
Basin No. 154

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71689
WELL NAME (if applicable): PW-2A

1. OWNER/CLIENT NAME: Midway Pan Gold
MAILING ADDRESS: 705 Ave. K, Ely, NV. 89301

DETAILED ADDRESS AT WELL LOCATION: Pan Mine, 25 Miles SE of Eureka, NV.
Subdivision Name: County: White Pine

2. PLS LOCATION SW ¼ NW ¼ 35 Sec 17 N/S 55 E
PERMIT/WAIVER NO. R-845/~~83692T~~ 83692T
issued by Water Resources Current Parcel No.

Latitude UTM E 607418 [X] NAD 27
Longitude UTM N 4350966 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[ ] New Well [ ] Deepen: Orig WL#
[X] Replacement: Original well log #
[ ] Recondition: Original well log #

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Monitor
[X] Mining / Dewater [ ] Com / Ind [ ] Stock
[ ] Test / Other [ ] Mun / QM [ ] Rec

5. WELL TYPE
[ ] Auger [ ] Rotary [ ] RVC
[ ] Air [ ] Mud [ ] Sonic
[X] Other Flooded

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Alluvium			0	5
Chainman formation			5	180
Johanna formation			180	240
Pilot shale			240	970
Devils gate formation			970	1360

NAD 27
39.302467°N
115.754370°W

Date started: 8-Feb, 20 15
Date completed: 11-Mar, 20 15

7. WATER QUALITIES
Static water level: 602 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: warm ° Fahrenheit
Water Quality: good

8. WELL TEST DATA
Test Method: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
325	6	1

9. CONSTRUCTION
Depth Drilled: 1360 Feet Depth Cased: 1350 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
31	Inches	0	Feet	50	Feet
24	Inches	50	Feet	1360	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
26	102.62	.375	0	50
16	62.58	.375	+2	1350
2.375	3.65	.154	+2	

ANNULAR MATERIALS
Sanitary Seal [X] Yes [ ] No

[X] Neat Cement	0	to	100	[ ] Pumped	[X] Poured
[X] Cement Grout	1344	to	1360	[X] Pumped	[ ] Poured
[ ] Concrete Grout		to		[ ] Pumped	[ ] Poured
[X] Bentonite Chips	100	to	105	[ ] Pumped	[X] Poured
[X] Gravel Pack [> 0.2 in.]	105	to	1344	[ ] Pumped	[X] Poured
[ ] Sand Pack [< 0.2 in.]		to		[ ] Pumped	[ ] Poured
[ ] Other, explain:		to		[ ] Pumped	[ ] Poured

PERFORATIONS:
Type of perforation: Louvered
Size of perforation: 0.125

From	Feet	To	Feet
1030	Feet	1330	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: Boart Longyear (Contractor)
Address: 2745 California Ave., SLC., UT. 84104 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0021976
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2130
Signed: (By driller performing actual drilling on site or contractor)
Date: 18-Mar-15

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. 1 of pg. 1

Replaces Unknown well log