STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122759
Permit No.
Basin No. 137B

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71458
WELL NAME (If applicable): DV-14-18

1. OWNER/CLIENT NAME Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480, Round Mountain, NV. 89045

DETAILED ADDRESS AT WELL LOCATION Round Mountain Mine, Round Mountain, NV
Subdivision Name: County: Nye

2. PLS LOCATION SE ¼ NW ¼ 19 Sec 10N N/S 44 E
PERMIT/WAIVER NO. M/O-1947 (Issued by Water Resources) Current Parcel No.

Latitude UTM E 492523.869 ☒ NAD 27
Longitude UTM N 4284613.398 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☒ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Gravel		no	0	130
Bedrock		Yes	130	500

NAD 27
38.711996°N
117.085976°W

Date started: 21-Oct, 20 14
Date completed: 25-Oct, 20 14

9. INSTRUCTION
Depth Drilled: 500 ~~420~~ Feet Depth Cased: 500 ~~420~~ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7.625	Inches	0	Feet	20	Feet
6.5	Inches	20	Feet	500	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.69	.154	+18	500

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to	54	☒ Pumped	☐ Poured	Neat Cement
☐ Cement Grout		to		☐ Pumped	☐ Poured	
☐ Concrete Grout		to		☐ Pumped	☐ Poured	
☒ Bentonite Chips	54	to	58	☐ Pumped	☒ Poured	3/8 Hole Plug
☒ Gravel Pack [> 0.2 in.]	58	to	500	☐ Pumped	☒ Poured	1/4 x 1/8 SRI
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured	
☐ Other, explain:		to		☐ Pumped	☐ Poured	

PERFORATIONS:
Type of perforation: Slot
Size of perforation: 0.02

From	Feet	To	Feet
60	Feet	500	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. WATER QUALITIES
Static water level: N/A Feet below land surface
Artesian Flow: No G.P.M. 0 P.S.I.
Water Temperature: N/A ° Fahrenheit
Water Quality: N/A

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
N/A		N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Boart Longyear (Contractor)
Address 2745 California Ave., SLC., UT. 84104 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0021976
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 3426
Signed: (By driller performing actual drilling on site or contractor)
Date: 29-Oct-14

RECEIVED 2014 NOV -3 PM 12:53 DIVISION OF WATER RESOURCES ENGINEERS OFFICE