

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 122403  
Permit No. \_\_\_\_\_  
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73118  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME GEISINGER  
MAILING ADDRESS 638 THOROBRED  
GARDNERVILLE, NV 89410

DETAILED ADDRESS AT WELL LOCATION 638 THOROBRED  
GARDNERVILLE, NV 89410  
Subdivision Name: \_\_\_\_\_ County: Douglas

2. PLS LOCATION SE ¼ SE ¼ 24 Sec 12N N/S 20 E  
PERMIT/WAIVER NO. 1220-24-810-018  
Issued by Water Resources Current Parcel No.

Latitude 38.88450°N UTM E \_\_\_\_\_  NAD 27  
Longitude 119.678795°W UTM N \_\_\_\_\_  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# N/A  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  
 Mining / Dewater  
 Test / Other  
 Irrigation  
 Com / Ind  
 Mun / QM  
 Monitor  
 Stock  
 Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

8. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OLD 8 5/8 WELL			0	220
COURSE GRAVELS			220	235
BROWN CLAY			235	248
OBSIDIAN GRAVELS		XXX	248	320
<i>deeper unknown log</i>				
<i>Lat 20 38.88450°N 119.678795°W</i>				

9. INSTRUCTION

Depth Drilled: 100 Feet Depth Cased: 100 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>7 7/8</u> Inches	<u>220</u> Feet
	<u>320</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>4.26</u>	<u>.216</u>	<u>200</u>	<u>320</u>

ANNULAR MATERIALS

Sanitary Seal  Yes  No

Neat Cement N/A to \_\_\_\_\_  Pumped  Poured

Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Bentonite Chips \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack [ > 0.2 in. ] N/A to \_\_\_\_\_  Pumped  Poured

Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

PERFORATIONS:

Type of perforation: FACTORY MILL SLOT

Size of perforation: 0.032

From 260 Feet To 300 Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

Date started: 22-Apr, 20 15  
Date completed: 28-Apr, 20 15

7. WATER QUALITIES

Static water level: 145 Feet below land surface

Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water Temperature: 52 ° Fahrenheit

Water Quality: GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision. This report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.  
Contractor

Address 20 KIT KAT DRIVE CARSON CITY, NV 89706  
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: \_\_\_\_\_

Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): \_\_\_\_\_

Signed: [Signature]  
By driller performing actual drilling or as a contractor

Date: 5/15/2015

8. WELL TEST DATA

Test Method:	Baller	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.		Draw Down (Feet Below Static)	Recorded Time (Hours)
<u>25+</u>		<u>50</u>	<u>3 HRS</u>