STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122825
Permit No. 17957
Basin 056

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71900 [redacted]

1. OWNER Paul Andriola
MAILING ADDRESS HC61 Box 6120 Lee Renfro Rd Austin NV 89310

ADDRESS AT WELL LOCATION Lee Renfro rd Austin NV 89310
Subdivision Name:
County: Lander

2. LOCATION NW ¼ NW ¼ Sec 31 T 17 N/S R 42 E
PERMIT/WAIVER No. 17957
Issued by Water Resources
Parcel No.

Latitude
Longitude
UTM E 0473656 ☒ NAD 27
N 4358311 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
MC Sands & Gravels		0	130	
Brown Clay		130	150	
Sands & Gravels		150	200	
Cobbles		200	270	
Clay stringers		270	275	
Sands & Gravels		275	310	
Clays stringers/U		310	394	
Sands & Gravels				

RECEIVED 2014 OCT 27 PM 12:48 STATE ENGINEERS OFFICE

NAD 27
39.375749°N
117.305848°W

Date started: 10-14, 20 14
Date completed: 10-19, 20 14

7. Water Level
Static water level: 50' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1000+		12

9. WELL CONSTRUCTION
Depth Drilled 394 Feet Depth Cased 394 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
26	Inches	0	Feet	30	Feet
22	Inches	30	Feet	394	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	52.32	3.312	0	394

Perforations:
Type of perforation Machine slot
Size of perforation .080
From 100 feet to 394 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 100 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 105 to 394 ☐ Pumped ☒ Poured
Type: 3/8 round
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Corp
Contractor
Address PO Box 888 Fallon NV 89407
Contractor

Nevada contractor's license number issued by the State Contractor's Board 0011752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199

Signed [signature]
By driller performing actual drilling on-site or contractor
Date 10-22-14

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) Replaces Well log 5573 (O) 627