

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 122891  
Permit No. \_\_\_\_\_  
Basin No. 103

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73123  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME JOHN FISHER  
MAILING ADDRESS 1320 HWY 395  
MINDEN, NV 89423

DETAILED ADDRESS AT WELL LOCATION 1565 CHIQUITA STREET  
MINDEN, NV 89423

Subdivision Name: \_\_\_\_\_ County: Douglas

2. PLS LOCATION SE 1/4 SE 1/4 34 Sec 14 N1S 20 E  
PERMIT/WAIVER NO. DOM-15-36 1420-34-811-018  
Issued by Water Resources Current Parcel No.

Latitude 39.028533°N UTM E  NAD 27  
Longitude 119.718159°W UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Corn / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
COURSE DG SANDS			3	95
BROWN CLAY			95	164
OBSIDIAN SANDS			164	175
BROWN CLAY			175	205
FRACTURED OBSIDIAN GRAVEL		XXX	205	260

7. WATER QUALITIES  
Static water level: 95 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: 52° ° Fahrenheit  
Water Quality: GOOD

9. INSTRUCTION  
Depth Drilled: 260 Feet Depth Cased: 260 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>11</u>	<u>0</u>	<u>260</u>	<u>260</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>+2</u>	<u>20</u>
<u>6 5/8</u>	<u>4.26</u>	<u>.216</u>	<u>20</u>	<u>260</u>
<u>SDR 21</u>				

ANNULAR MATERIALS

Sanitary Seal  Yes  No

Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Cement Grout 0 to 60  Pumped  Poured

Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Bentonite Chips \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack [ > 0.2 in. ] 60 to 260  Pumped  Poured

Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

PERFORATIONS:

Type of perforation: FACTORY MILL SLOT

Size of perforation: 0.032

From 220 Feet To 260 Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

8. WELL TEST DATA

Test Method:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<u>25</u>	<u>65</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision. This report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.  
Contractor

Address 20 KIT KAT DRIVE CARESON CITY, NV 89706  
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 0055548

Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905

Signed: [Signature]  
Driller performing actual drilling on well or contractor

Date: 8/3/2015