STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122887
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72979
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME JIM WENINGER
MAILING ADDRESS 1964 AMBERWOOD
CARSON CITY, NV 89703

DETAILED ADDRESS AT WELL LOCATION 7460 CENTER DRIVE
CARSON CITY, NV 89701
Subdivision Name: *County:* Carson City

2. PLS LOCATION SW ¼ SE ¼ 5 Sec 14 N/S 20 E
PERMIT/WAIVER NO. DOM-15-08 *Issued by Water Resources* 09-821-10 *Current Parcel No.*

Latitude 39.10133°N UTM E ☐ NAD 27
Longitude 119.76076°W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
DG SANDS			3	85
BROWN CLAY			85	129
BROWN SILTY SANDS			129	135
GRAY SILTY SANDS			135	165
GRAY CLAY			165	178
GRAY DG SANDS		XXX	178	220

Nad 27
39.16421°N
119.75972°W

Date started: 10-Aug , 20 15
Date completed: 12-Aug , 20 15

7. WATER QUALITIES
Static water level: 65 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 49° ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
25	75	3 HRS

9. *INSTRUCTION*
Depth Drilled: 220 Feet Depth Cased: 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.26	.216	+2	20
6 5/8	13.03	.188	20	220
SDR 21				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	60	☐ Pumped	☒ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	60	to	220	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: 0.032

From 180 Feet	To 220 Feet		
From Feet	To Feet		
From Feet	To Feet		
From Feet	To Feet		
From Feet	To Feet		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 0055548
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1905
Signed: *by driller performing actual drilling or for contractor*
Date: 8/17/2015

RECEIVED 2015 AUG 19 AM 11:20 STATE ENGINEER'S OFFICE

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.