STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122973
Permit No. 54209
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36775

1. OWNER THOMAS F. LOBESK / PIONEER WELL ASS
MAILING ADDRESS 7355 ACKERMAN AV.
LAS VEGAS NV. 89131
ADDRESS AT WELL LOCATION 7375 ACKERMAN AV.
LAS VEGAS NV. 89131
Subdivision Name:
County: CLARK

2. LOCATION SE ¼ SW ¼ Sec 10 T 19 R 60 E
Latitude 36° 18' 23.70" Longitude 115° 15' 19.70"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84
PERMIT/WAIVER No. 54209 (Issued by Water Resources) 125-10-406-003 (Parcel No.)

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
NEW WELL SANDED + SILTED IN				
CLEAN OUT FILL SILT + SAND		475	500	25
CLAY		500	525	25
CLAY + GRAVEL		525	530	5
3/4-PEA GRAVEL	W.B	530	545	15
CEMENTED SAND + GRAVEL		545	565	20
SANDY GRAVE	W.B	565	570	5
BROWN SAND STONE		570	595	25

DIVISION OF WATER RESOURCES RECEIVED JUN 1 2 2015

Date started: 5-4 , 20 15
Date completed: 5-15 , 20 15

7. Water Level
Static water level: 78 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 595 Feet Depth Cased 595 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6" Inches		500 Feet	595 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (inches)	From (Feet)	To (Feet)
4½	4.33	SDR.17 - 0.291	595	SURFACE

Perforations:
Type of perforation FACTORY SCREEN
Size of perforation 0.032 X 4 ROW
From 595 feet to 335 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout EXISTING ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type: EXISTING
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING LLC (Contractor)
Address 1170 DARCY LN. 89060 (Contractor)
PAHRUMP NV.
Nevada contractor's license number issued by the State Contractor's Board 77029
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed Dennis Brown (By driller performing actual drilling on-site or contractor)
Date 6-15-2015

Rev. 12/06

USE ADDITIONAL SHEETS IF NECESSARY

36.3066172
-115.2546318
NAD 27