STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123011
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36846

1. OWNER C.C. Public Right-of-Way
MAILING ADDRESS 500 S. Grand Central Pkwy
Las Vegas NV. 89155-0000

ADDRESS AT WELL LOCATION No Address Public Right-of-Way
Subdivision Name: Well #26 County: Clark

2. LOCATION NE¼ NE ¼ Sec 29 T 21 N/S R 62 E
PERMIT/WAIVER No. MO-3020 (Issued by Water Resources) 161-29-599-015 (Parcel No.)
Latitude 36° 5' 48.3" Longitude - 115° 3' 50.42"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill 3" AC Cover Agg. base		0	1½	1½
Silty Sand		1½	3	1½
Silty Clay		3	13	8
SAND w/ silt	wet	11	13	2
SILTY CLAY		13	25	12

DCNR/DWR/SNBO RECEIVED MAR 17 2015

Date started 2/10, 20 15
Date completed 2/10, 20 15

7. Water Level
Static water level: 14' 7" feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NOTE: Dewatering wells nearby have Depressed the water level		

9. WELL CONSTRUCTION
Depth Drilled 25' Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6½	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" Sch 40 PVC		ASTM F480	0	25

Perforations:
Type of perforation Factory Slots
Size of perforation .020"

From 10	feet to	25'	feet
From	feet to		feet
From	feet to		feet
From	feet to		feet
From	feet to		feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☒ Concrete Grout	to		☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 8 to 25 ☐ Pumped ☒ Poured
Type: #12 Silica Sand
Bentonite Chips: ☒ Yes ☐ No 6 to 8 ☐ Pumped ☒ Poured
Type: 3/8 Bentonite Hole Plug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Elite Drilling Inc
Address (Contractor) 4255 W. Post Rd. Las Vegas, NV 89118
Nevada contractor's license number issued by the State Contractor's Board 054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1944
Signed Thomas M. Beall (By driller performing actual drilling on-site or contractor)
Date 3/13/15

USE ADDITIONAL SHEETS IF NECESSARY

36.0967762
-115.0631758
NAD 29

(Rev. 05-06)
(NSPO 3-08)
(O) 627