STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123020
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36849

1. OWNER Clark County Public Right of Way
MAILING ADDRESS 500 S. Grand Central Pkwy.
Las Vegas, NV. 89155-000
ADDRESS AT WELL LOCATION None - Hacienda Ave.
Clark
Subdivision Name: County:

2. LOCATION SE ¼ NE ¼ Sec 29 T 21 N OR 62 E
PERMIT/WAIVER No MO-3024 Issued by Water Resources
161-29-619-014 Parcel No.
Latitude 36°5' 34.60"
Longitude -115°4' 4.35"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84
Client # PZ-21

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL A Cover Agg. bags		0	1	1
Silty CLAY		1	12	11
SILTY SAND	Wet	12	15	3
SILTY CLAY		15	40	25

DCNR/DWR/SNBC
RECEIVED
MAY 15 2015

Date started: 4/30, 20 15
Date completed: 4/30, 20 15

7. Water Level
Static water level: 17.5' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality: Water level influenced By Nearby Pumping wells

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA		

9. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 Inches		0 Feet	40 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" sch 40 PVC ASTM F-480			0	40

Perforations:
Type of perforation Factory Slots
Size of perforation .020
From 10 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 6 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 8 to 40 ☐ Pumped ☒ Poured
Type: #12 Silica Sand
Bentonite Chips: ☒ Yes ☐ No 6 to 8 ☐ Pumped ☒ Poured
Type: 3/8 Bentonite Hole Plug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling, Inc. Contractor
Address 4255 W. Post Rd. Contractor
Las Vegas, NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1944 M
Signed Thomas A. Beall By driller performing actual drilling on-site or contractor
Date 5/15/15

(Rev. 08-08)
USE ADDITIONAL SHEETS IF NECESSARY

36.0929706
-115.2670452
NAD 27

(NSPO 3-08)
(O) 627