STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123045
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37867
WELL NAME (If applicable): MW-6

1. OWNER/CLIENT NAME: Bakolas Holdings Placid LLC
MAILING ADDRESS: 1400 Griffith Ave Las Vegas,NV,89104

DETAILED ADDRESS AT WELL LOCATION: 335 East Arby Avenue
Las Vegas, NV, 891129
Subdivision Name: County: Clark

2. PLS LOCATION: SE ¼ SE ¼ 4 Sec 22 N/S 61 E
PERMIT/WAIVER NO. MO - 3065 (Issued by Water Resources) 177-04-802-001 (Current Parcel No.)

Latitude: 36*03'29.82"N UTM E: ☐ NAD 27
Longitude: 115*09'25.39"W UTM N: ☑ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☑ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt			0	2.5"
Brown silty sand w/gravel and			2.5"	30
some clay				
Caliche			30	34
Light brown silty clay/some sand				
and gravel			34	45
Decrease in sand no gravel			45	47
Increase in silt and sand no gravel				
Decrease in sand and silt				
some gravel			47	80

Date started: 18-Jul, 20 15
Date completed: 18-Jul, 20 15

7. WATER QUALITIES
Static water level: 74 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: 80 Feet Depth Cased: 80 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.25	Inches	0	Feet	80	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.68	0.154	0	80

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☑ Cement Grout	0	to	46	☑ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☑ Bentonite Chips	46	to	48	☐ Pumped	☑ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☑ Sand Pack [< 0.2 in.]	48	to	80	☐ Pumped	☑ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02

From	Feet	To	Feet
50	Feet	80	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: National EWP (Contractor)
Address: 5241 Schirlls st. Las Vegas, NV, 89118 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2512-ltd
Signed: Bob (By driller performing actual drilling on site or contractor)
Date: 8-15-15

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

DCNR/DWR/SNBO
RECEIVED
AUG 14 2015

36.0583102
-115.1562225
NAD 27