

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67370

1. OWNER Frank GODECKE ADDRESS AT WELL LOCATION 1590 Godecke
 MAILING ADDRESS 1590 Godecke GU NV
00 NO 99415

2. LOCATION SE 1/4 NE 1/4 Sec 03 T. 12 N/S R. 20 E. Douglas County
 PERMIT NO. Dom 15-47 Parcel No. 1220-03-000-017 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Dirt & Clay</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Gravel</u>		<u>3</u>	<u>75</u>	<u>72</u>
<u>Clay</u>		<u>72</u>	<u>79</u>	<u>7</u>
<u>Gravel & Clay</u>		<u>79</u>	<u>83</u>	<u>4</u>
<u>Small Gravel</u>		<u>83</u>	<u>110</u>	<u>27</u>
<u>Soft Brown Clay</u>		<u>110</u>	<u>117</u>	<u>7</u>
<u>Small - Large Gravel</u>		<u>117</u>	<u>150</u>	<u>133</u>
<u>3755.880</u>				
<u>119 42.910</u>				
<u>NAD</u>				
<u>83.74</u>				
<u>Had 27</u>				
<u>38.4 314.26 N</u>				
<u>119.7 1415.6 W</u>				
<u>replaces unknown log</u>				

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 250 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+2</u>	<u>10</u>
<u>6 5/8</u>		<u>SDR 21</u>	<u>10</u>	<u>250</u>

Perforations:
 Type perforation Factory
 Size perforation 3/32

From _____ feet to _____ feet
 From 190 feet to 250 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 100 feet to 250 feet

Date started 7-30-15, 20____
 Date completed 7-31-15, 20____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>175 FT</u>	<u>50+</u>	<u>3</u>

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow NO G.P.M. 50+ P.S.I.
 Water temperature 59 °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BLAIN DRILLING & PUMP CO INC
 Address P.O. Box 1255
Carson City, NV 89702

Nevada contractor's license number issued by the State Contractor's Board 564978A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1321

Signature [Signature]
 By driller performing actual drilling on site or contractor

Date 8-8-15