

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2057  
 Candy Parcel 2196 Gena Heights

1. OWNER TEDDY & Tessa McKoul ADDRESS AT WELL LOCATION 2196 Gena Heights  
 MAILING ADDRESS 1640 Blarney Dr  
 2. LOCATION NE 1/4 NE 1/4 Sec 16 T. 13 N/S R. 19 E Douglas County  
 PERMIT NO. DM 15-28 Parcel No. 13A-16-001012 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay Cobble		0	130	130
Black frac.		130	178	48
Clay & Black Fra.		178	205	37
Frac with Multi Colored Rock		205	250	45
Boulder		250	263	13
Black frac. with MULT. Colored Rock		263	390	127

38° 99M2C  
 119° 84601  
 NAD 83-74  
 NAD 27  
 38.994352° N  
 119.444997° W

8. WELL CONSTRUCTION  
 Depth Drilled 390 Feet Depth Cased 390 Feet

HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 15.5 Feet  
7 7/8 Inches 15.5 Feet 390 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>390</u>

Perforations:  
 Type perforation Factory  
 Size perforation 1/16  
 From 370 feet to 390 feet  
 From 330 feet to 350 feet  
 From 290 feet to 310 feet  
 From 250 feet to 270 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 102  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 102 feet to 390 feet

9. WATER LEVEL  
 Static water level 125 feet below land surface  
 Artesian flow NO G.P.M. 40+ P.S.I.  
 Water temperature 61 °F Quality Clear

Date started 8-11-15, 20\_\_\_\_  
 Date completed 8-14-15, 20\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>300 FT</u>	<u>40+</u>	<u>4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BLAIN DRILLING & PUMP CO INC.  
 Address Carson City NV 89701  
 Nevada contractor's license number \_\_\_\_\_ issued by the State Contractor's Board  
 Nevada driller's license number issued by \_\_\_\_\_ Division of Water Resources, the on-site driller  
 Signed C. Johnson  
 Date 8-18-15

CONTRACTOR'S LICENSE NO. 125  
 ENGINEER'S OFFICE  
 2015-26-7998  
 352  
 21