STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123114
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74269
WELL NAME (if applicable): well#2

1. OWNER/CLIENT NAME BIA - Washoe Tribe of NV & CA
MAILING ADDRESS 311 E.Washington St. Carson City NV 89701

DETAILED ADDRESS AT WELL LOCATION 919 N HWY 395
, Douglas County NV
Subdivision Name: County:

2. PLS LOCATION SE ¼ SW ¼ 11 Sec ~~12S~~ 12N N/S 20 E
PERMIT/WAIVER NO. DW-117 (Issued by Water Resources) 1220110020 09 (Current Parcel No.)

Latitude 38.912018' N UTM E ☐ NAD 27
Longitude 119.709030' W UTM N x NAD 83/WGS 84

3. WORKED PERFORMED
x New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
x Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
x Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
sandy cobble fill			0	
hard silty clay & rock				3
hard silty clay & rock			3	
silty sand & cobble				8
silty sand & cobble			8	
silty clay, sand cobble				20
silty clay, sand cobble			20	30
Annular Materials				
0-10' - Steel Spacer				
~~10'-12' - Bentonite Seal~~				
NAD 27				
38.912111				
119.708072				

Date started: 31-Jul, 20 15
Date completed: 31-Jul, 20 15

7. WATER QUALITIES
Static water level: 9ft Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: 30 Feet Depth Cased: 30 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24 Inches		0 Feet	30 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	12	5/8	0	30

ANNULAR MATERIALS
Sanitary Seal x Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
Bentonite Chips	8	to 10	☐ Pumped	Poured
x Gravel Pack [> 0.2 in.]	½ 10	to 30	☐ Pumped	x Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain: 3/8 pea gravel		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: machine slot
Size of perforation: 0.032

From	To
10 Feet	30 Feet
Feet	Feet
Feet	Feet
Feet	Feet
Feet	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Viking Drillers, Inc (Contractor)
Address 5950 Granite Lake Drive, Granite Bay, CA 95746 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board. 0034680
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller) 2361
Signed: (By driller performing actual drilling on site or contractor)
Date: 8/13/2015

RECEIVED 2015 AUG 19 AM 11:20 STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. 1 of pg.