

YEMW6

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 123126
Permit No.
Basin 108

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70124

1 OWNER LYON COUNTY SCHOOLS ADDRESS AT WELL LOCATION SAME
MAILING ADDRESS 112 N. CALIFORNIA ST YERINGTON, NV
Subdivision Name: County: LYON
2 LOCATION NW SW 1/4 Sec 14 T 130 S R 250 E Latitude UTM E 313012.8 NAD 27
PERMIT/WAIVER No. 201-122-01 Longitude N 431777.0 NAD 83/WGS 84

3 TYPE OF WELL Is this well being plugged because a replacement well was drilled? No Is there an existing well log? No
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
If yes, what is replacement well NOR? If yes, what is NDWR well log #?

4 EXISTING WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet	
EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	SCH 40	PVC	0	30

Existing Perforations:
Type of perforation FACTORY SLOTTED
Size of perforation
From ? feet to ? feet
From ? feet to ? feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why:
Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used: NONE
From ? feet to ? feet Number of perms per linear foot
From ? feet to ? feet Number of perms per linear foot
From ? feet to ? feet Number of perms per linear foot
From ? feet to ? feet Number of perms per linear foot
From ? feet to ? feet Number of perms per linear foot
From ? feet to ? feet Number of perms per linear foot

5 WATER LEVEL
Static water level DRY feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	Pumped	Poured
0	30	feet	NEAT CEMENT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments
PRESSURE GROUTED & REMOVE TOP 5' OF CASING
NAD 27
38.989055°N
119.157991°W

Neat Cement Fluid Weight 94/5 lbs/gal
Bentonite Grout % bentonite
Date Started 8-4-15
Date Completed 8-4-15

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name GREGG DRILLING & TESTING Contractor
Address 950 Howe Rd Martinez, CA 94553 Contractor
Nevada contractor's license number issued by the State Contractor's Board C23-0038113
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2435-M
Signed [Signature] ENGINEERS OFFICE
Date 8-10-15

(Rev. 05-05)

USE ADDITIONAL SHEETS IF NECESSARY

Plugging Unknown Well log

RECEIVED
5 AUG 3 PM 1:18
ENGINEERS OFFICE