

MW 2

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY  
Log No. 173133  
Permit No.  
Basin 108

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70124  
SAME

1 OWNER LYON Co. Schools  
MAILING ADDRESS 112 N CALIFORNIA ST  
YERINGTON NV

ADDRESS AT WELL LOCATION  
Subdivision Name: County: LYON

2 LOCATION NW 1/4 SW 1/4 Sec 14 T 13 N SR 25 E  
PERMIT/WAIVER No. M/0549 D 1 001-122-01  
issued by Water Resources Parcel No.

Latitude UTM E 312993.3  
Longitude N 4317255  
 NAD 27  
 NAD 83/WGS 84

3 TYPE OF WELL  
 Domestic  
 Municipal/Industrial  
 Irrigation  
 Monitor  
 Test  
 Stock

is this well being plugged because a replacement well was drilled? NO  
Is there an existing well log? YES  
If yes, what is NDWR well log #? 59251

4 EXISTING WELL CONSTRUCTION  
Depth Drilled 25 Feet  
Depth Cased 25 Feet

7 WELL PLUGGING PROCEDURE  
Was well cleaned out to total depth?  yes  no  
If well was not cleaned out to total depth, please explain why:

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/2	SCH 40	PVC	0	25

Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no  
If casing was left in place, please show where additional perforations were made:

Existing Perforations:  
Type of perforation FACTORY SLOTTED  
Size of perforation 1.020  
From 10 feet to 25 feet

Additional Perforations:  
Type of perforater used: NONE

5 WATER LEVEL  
Static water level DRY feet below land surface  
Artesian flow G.P.M. P.S.I.  
Water temperature °F Quality

8 WELL PLUGGING MATERIALS  
Material Used  
From 0 feet to 25 feet NEAT CEMENT  Pumped  Poured

6 Additional Notes or Comments  
PRESSURE GROUTED & REMOVED TOP 5' OF CASING

Neat Cement Fluid Weight 94/5 lbs/gal  
Bentonite Grout % bentonite  
Date Started 8-4-15  
Date Completed 8-4-15

NAD 27  
38.988916°N  
119.158206°W

9 DRILLER'S CERTIFICATION  
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.  
Name GREBE DRILLING & TESTING Contractor  
Address 950 HOWARD MARTINEZ, CA 94553 Contractor  
Nevada contractor's license number issued by the State Contractor's Board C23-0038113  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2435-M  
Signed [Signature] By driller performing actual drilling on site or contractor  
Date 8-10-15

USE ADDITIONAL SHEETS IF NECESSARY  
Plugging well log 59251  
AUG 31 PM 1:18 RECEIVED ENGINEERS OFFICE