

ASP 1

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 123134
Permit No.
Basin 108

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

1 OWNER LYON Co. Schools ADDRESS AT WELL LOCATION SAME
MAILING ADDRESS 112 N CALIFORNIA ST
YERINGTON NV Subdivision Name: County: LYON

2 LOCATION NW 1/4 SW 1/4 Sec 14 T 13 S R 25 E Latitude UTM E 312993 NAD 27
PERMIT/WAIVER No. M/0549 C 001-193-01 Longitude N 4317754 NAD 83/WGS 84
Issued by Water Resources Parcel No.

3 TYPE OF WELL Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? No Is there an existing well log? YES
If yes, what is replacement well NOI? If yes, what is NDWR well log #? 59252

4 EXISTING WELL CONSTRUCTION
Depth Drilled 22 Feet Depth Cased 22 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why:

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>	<u>SCH 40</u>	<u>PVC</u>	<u>0</u>	<u>22</u>

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used: NONE

Existing Perforations:
Type of perforation FACTORY SLOTTED
Size of perforation 1.000
From 20 feet to 22 feet
From _____ feet to _____ feet

Type of perforator used: NONE
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

5 WATER LEVEL
Static water level DRY feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

6 Additional Notes or Comments
PRESSURE GROUT & REMOVE TOP 5' OF CASING

Material Used
From 0 feet to 22 feet NEAT CEMENT Pumped Poured
From _____ feet to _____ feet Pumped Poured

Neat Cement Fluid Weight 94/5 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 8-4-15
Date Completed 8-4-15

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name GREGG DRILLING & TESTING
Address 9.50 Howe Rd MARTINEZ, CA 94553
Nevada contractor's license number C 23-0038113
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 22355-1A
Signed _____
Date 8-10-15

NAD 27
38.988907° N
119.158206° W

By driller performing actual drilling on site or contractor
DIVISION OF WATER RESOURCES OFFICE
RECEIVED
SEP 11 PM 1:18

Plugging well log 59252