

YEMW.MR

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 123135
Permit No.
Basin 108

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70124

1 OWNER LYON Co. SCHOOLS
MAILING ADDRESS 112 N CALIFORNIA ST
VERINGTON, NV

ADDRESS AT WELL LOCATION SAME
Subdivision Name: County: LYON

2 LOCATION NW 1/4 SW 1/4 Sec 14 T 13 N R 25 E
PERMIT/WAIVER No. No. 349-21 001-122-01

Latitude UTM E 312991.5
Longitude N 4317752

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? NO
If yes, what is replacement well NOI?

Is there an existing well log? YES
If yes, what is NDWR well log #? 644228

4 EXISTING WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 1/2	50 H 40	PVC	0	25

If well was not cleaned out to total depth, please explain why:
Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:
Type of perforation FACTORY SLOTTED
Size of perforation 1.020
From 5 feet to 25 feet

If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used: NONE

5 WATER LEVEL
Static water level DRY feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

8 WELL PLUGGING MATERIALS
Material Used
From 0 feet to 25 feet NEAT CEMENT Pumped Poured

6 Additional Notes or Comments
PRESSURE GROUT USING NEAT CEMENT - REMOVE TOP 5' OF CASING

Neat Cement Fluid Weight 94/5 lbs/gal
Bentonite Grout % bentonite
Date Started 8-3-15
Date Completed 8-3-15

NAD 27
38.988888° N
119.158229° W

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name GREGG DRILLING & TESTING Contractor
Address 950 HOWE RD MARTINEZ, CA 94553 Contractor
Nevada contractor's license number issued by the State Contractor's Board C23-0038113
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2435-A1
Signed [Signature] By driller performing actual drilling on site or contractor
Date 8-10-15

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED
AUG 31 PM 1:18
STATE ENGINEERS OFFICE

Plugging Well log 64428