

YERW-1

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 123138
Permit No.
Basin 108

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70124

1 OWNER LYON Co. School ADDRESS AT WELL LOCATION SAME
MAILING ADDRESS 112 N CALIFORNIA ST Subdivision Name: _____ County: LYON
VERINGTON, NV

2 LOCATION NW 1/4 SW 1/4 Sec 14 T 13 N R 25 E Latitude 31299.7 UTM E 31299.7 NAD 27
PERMIT/WAIVER No. 17/0549E 001-122-01 Longitude _____ N 43177.7 NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3 TYPE OF WELL Domestic Irrigation Test Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? NO Is there an existing well log? YES
If yes, what is replacement well NO? _____ If yes, what is NDWR well log #? 59255

4 EXISTING WELL CONSTRUCTION
Depth Drilled 22 Feet Depth Cased 22 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>	<u>SCH 40</u>	<u>PVC</u>	<u>0</u>	<u>22</u>

Existing Perforations:
Type of perforation FACE & SLOTTED
Size of perforation 1020
From 20 feet to 22 feet
From _____ feet to _____ feet

5 WATER LEVEL
Static water level DRY feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

6 Additional Notes or Comments
PRESSURE GROUT CUT OFF TOP 5' OF CASING

NAD 27
38.988753°N
119.158225°W

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used: NONE
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

8 WELL PLUGGING MATERIALS
From 0 feet to 22 feet NEAT CEMENT Pumped Poured
From _____ feet to _____ feet Pumped Poured

Neat Cement Fluid Weight 94/5 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 8-3-15
Date Completed 8-3-15

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name GROSS DRILLING & TESTING Contractor
Address 950 HOWE RD MARTINEZ, CA 94553 Contractor
Nevada contractor's license number C23-0038113
issued by the State Contractor's Board
Nevada driller's license number issued by the 2435 M
Division of Water Resources, the on-site driller
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 8-10-15

RECEIVED
AUG 31 PM 1:18
ENGINEERS OFFICE

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-06)

Plugging well log 59255