STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123142
Permit No. 84839T
Basin No. 177

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69105
WELL NAME (if applicable):

1. OWNER/CLIENT NAME Scott & Laurel Egbert
MAILING ADDRESS HC60 Box 135
Wells, NV 89835

DETAILED ADDRESS AT WELL LOCATION HC60 Box 135
Subdivision Name: County: Elko

2. PLS LOCATION NW ¼ NE ¼ 4 Sec 35 N/S 62 E
PERMIT/WAIVER NO. 84839T (Issued by Water Resources) 008-320-006 (Current Parcel No.)

Latitude 40 57 03.6 UTM E ☐ NAD 27
Longitude 114 58 30.9 UTM N X NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top Soil			0	10
Sand, 80% Gravel			10	220
Boulders			220	370
Gravel			370	400
Sand, 10% Gravel			400	480
Sand, Gravel, 50% Boulders			480	500

NAD 27
40.951126°N
114.974358°W

Date started: 16-Jun, 20 15
Date completed: 18 July, 20 15

9. CONSTRUCTION
Depth Drilled: 500 Feet Depth Cased: 500 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	500	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/FL (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"		.375	+2	500

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0 to 50	☒ Pumped	☐ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ Bentonite Chips	to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	50 to 500	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]	to	☐ Pumped	☐ Poured
☐ Other, explain:	to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: mill
Size of perforation: 5/32 x 2 1/2 x 16

From	Feet	To	Feet
120		160	
200		240	
280		500	

7. WATER QUALITIES
Static water level: 18 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 58 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
1500	332	33.75

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Gardner Brothers Drilling, Inc (Contractor)
Address PO Box 965, Enterprise, UT 84725 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0068459
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2468
Signed: (By driller performing actual drilling on site or contractor)
Date: Aug. 24, 2015 Sent orig. 7-29-15

RECEIVED 2015 AUG 27 AM 8:01 ENGINEERS OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.