STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 123145
Permit No.
Basin No. 137B

NOTICE OF INTENT NO. 73258
WELL NAME (*if applicable*): DW-76

1. OWNER/CLIENT NAME Round Mountain Gold Corp.
MAILING ADDRESS PO Box 480,
Round Mountain, NV. 89045

DETAILED ADDRESS AT WELL LOCATION Round Mountain Mine,
Round Mountain, NV. 89045
Subdivision Name: *County:* Nye

2. PLS LOCATION SW ¼ NW ¼ 29 Sec 10 (N)/S 44 E
PERMIT/WAIVER NO. 83333 (*Issued by Water Resources*) Order 1233 (*Current Parcel No.*)

Latitude UTM E 493890 [X] NAD 27
Longitude UTM N 4283067 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Deepen: Orig WL#
[ ] Replacement: Original well log #
[ ] Recondition: Original well log #

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Monitor
[X] Mining / Dewater [ ] Com / Ind [ ] Stock
[ ] Test / Other [ ] Mun / QM [ ] Rec

5. WELL TYPE
[ ] Auger [ ] Rotary [ ] RVC
[ ] Air [ ] Mud [ ] Sonic
[X] Other Flooded Rev

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
White Clay			0	30
Light grey rock w/clay			30	40
Light grey rock			40	120
Grey rock w/ white clay			120	380
Light green / grey granite			380	805

NAD 27
38.698070°N
117.070262°W

Date started: 22-Jul , 20 15
Date completed: 18-Aug , 20 15

7. WATER QUALITIES
Static water level: 231 Feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I.
Water Temperature: 51.8 ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
30	471	2

9. INSTRUCTION
Depth Drilled: Feet 805 Depth Cased: 800 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
26	Inches	0	Feet	60	Feet
19	Inches	60	Feet	805	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
22	86.6	.375	0	60
12.75	33.375	.250	+2	800
2.375	3.65	.145	+2	760

ANNULAR MATERIALS
Sanitary Seal X Yes [ ] No

[X] Neat Cement	0	to 160	[X] Pumped	[ ] Poured
[ ] Cement Grout		to	[ ] Pumped	[ ] Poured
[ ] Concrete Grout		to	[ ] Pumped	[ ] Poured
[X] Bentonite Chips	160	to 170	[ ] Pumped	X Poured
[X] Gravel Pack [> 0.2 in.]	170	to 805	[ ] Pumped	X Poured
[ ] Sand Pack [< 0.2 in.]		to	[ ] Pumped	[ ] Poured
[ ] Other, explain:		to	[ ] Pumped	[ ] Poured

PERFORATIONS:
Type of perforation: Louvered / Millslot
Size of perforation: 0.125

From	Millslot 180	Feet	To	320	Feet
From	Louvered 320	Feet	To	780	Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Boart Longyear (Contractor)
Address 2745 California Ave., SLC., UT. 84104 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board.* 0024976
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)* 2486
Signed: (*By driller performing actual drilling on site or contractor*)
Date: 24-Aug-15

RECEIVED 2015 AUG 27 AM 8:58 ENGINEERS OFFICE

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. 1 of pg. 1