STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123189
Permit No. 84762-84770, 84772
Basin No. 033A

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72054
WELL NAME (If applicable): N/A

1. OWNER/CLIENT NAME McClintick Farms
MAILING ADDRESS Po Box 219 Orovada NV 89425

DETAILED ADDRESS AT WELL LOCATION 3/4 mile sw of Valley & King River Rd Orovada NV 89425
Subdivision Name: County: Humbolt

2. PLS LOCATION NE¼ SW ¼ 32 Sec 43 N/S 37 E
PERMIT/WAIVER NO. 84770-84772 (Issued by Water Resources) Current Parcel No.

Latitude 41° 33.756 N UTM E
Longitude 117° 50.347 W UTM N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # 9346
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top soil Course Sands			0	50
Sands gravels Brown clays			50	290
Fine Sands Brown clays			290	386
loose Sands sticky Brown clays			386	418
Course Small gravels Brown clays			418	450
gravels Course Sands sticky Brown clays			450	482
very Brown sticky clays			482	546
Brown Sandy clays Tai Color gravels			546	578
Brown clays and gravels			578	610
Brown sticky clays			610	620
NAD27 41.567600°N 117.839117°W				

Date started: 8-7, 20 15
Date completed: 8-11, 20 15

9. CONSTRUCTION
Depth Drilled: 620 Feet Depth Cased: 610 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
36"	Inches	0 Feet	50 Feet
24"	Inches	50 Feet	620 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30"		.375	0	50
16"		.375	+18"	610

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0 to 50	☒ Pumped	☐ Poured	
☐ Cement Grout	to	☐ Pumped	☐ Poured	
☐ Concrete Grout	to	☐ Pumped	☐ Poured	
☐ Bentonite Chips	to	☐ Pumped	☐ Poured	
☒ Gravel Pack [> 0.2 in.]	0 to 620	☐ Pumped	☐ Poured	
☐ Sand Pack [< 0.2 in.]	to	☐ Pumped	☐ Poured	
☐ Other, explain:	to	☐ Pumped	☐ Poured	

PERFORATIONS:
Type of perforation: Triple mill
Size of perforation: 80-Slot

From	To
179 Feet	600 Feet
Feet	Feet
Feet	Feet
Feet	Feet
Feet	Feet

RECEIVED 2015 AUG 28 AM 11:03 ENGINEERS OFFICE

7. WATER QUALITIES
Static water level: 97 Feet below land surface
Artesian Flow: NO G.P.M. N/A P.S.I.
Water Temperature: 43 ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Hydro Resources (Contractor)
Address 4975 W. Winn Blvd Winnemucca NV 89445 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 56797
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2289 Tobias A Trujillo
Signed: Tobias R Trujillo (By driller performing actual drilling on site or contractor)
Date:

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Replaces well log 9346