STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123206
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 37857
WELL NAME (If applicable): MW-2

1. OWNER/CLIENT NAME Argyris Enterprise
MAILING ADDRESS 9948 Keiter Valley St
Las Vegas, NV, 89178

DETAILED ADDRESS AT WELL LOCATION 5680 S. Pecos Rd.
Las Vegas, NV, 89120
Subdivision Name: County: Clark

2. PLS LOCATION SW¼ SW ¼ 30 Sec 21 N/S 62 E
PERMIT/WAIVER NO. M0-3056 (Issued by Water Resources) 161-30-401-020 (Current Parcel No.)

Latitude 36°05'11.09" N
Longitude -115°06'01.49" W
UTM E
UTM N
☑ NAD 27
☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☑ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

| Material Encountered | Lost Circ. | Water Strata | From | To |
|---|---|---|---|---|
| Gray Sandy Silt w/Trace Gravel, Black Staining. | | | 0 | 5' |
| Light Brown Silt w/Sand & Some gravel. | | | 5' | 10' |
| Grey Silt w/Trace gravel | | | 10' | 15' |
| Lean Clay w/gravel | | | 15' | 20 |

DCNR/DWR/SNBO RECEIVED MAY 29 2015

Date started: 5/1, 20 15
Date completed: 5/1, 20 15

7. WATER QUALITIES
Static water level: 15.82 Feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Recorded Time (Hours) |
|---|---|---|
| | | |

9. CONSTRUCTION
Depth Drilled: 25 Feet Depth Cased: 25 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10.25 | Inches | 0 Feet | 25 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.50 | 2.01 | 0.237 | 0 | 25 |

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

| | | | | |
|---|---|---|---|---|
| ☑ Neat Cement | 0 to 6 | ☑ Pumped | ☐ Poured |
| ☐ Cement Grout | to | ☐ Pumped | ☐ Poured |
| ☐ Concrete Grout | to | ☐ Pumped | ☐ Poured |
| ☑ Bentonite Chips | 6 to 8 | ☐ Pumped | ☑ Poured |
| ☐ Gravel Pack [ > 0.2 in. ] | to | ☐ Pumped | ☐ Poured |
| ☑ Sand Pack [ < 0.2 in. ] | 8 to 25 | ☐ Pumped | ☑ Poured |
| ☐ Other, explain: | to | ☐ Pumped | ☐ Poured |

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02

| From | To |
|---|---|
| 10 Feet | 25 Feet |
| Feet | Feet |
| Feet | Feet |
| Feet | Feet |
| Feet | Feet |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP (Contractor)
Address 5241 Schirlls St. Las Vegas, NV 89118 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2512-LTD
Signed: Bob (By driller performing actual drilling on site or contractor)
Date: 5/21/15

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.03658 05
-115.1004 1389
NAD 27