

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123213
Permit No. _____
Basin No. _____

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 3785 G
WELL NAME (if applicable): PC-957B

1. OWNER/CLIENT NAME Nevada Environmental Response Trust DETAILED ADDRESS AT WELL LOCATION 8200 E. Russell Rd Henderson, NV, 89122
MAILING ADDRESS 35E Walker Dr #1550 Chicago IL 60601-2314 Subdivision Name _____ County Clark

2. PLS LOCATION SW 1/4 SW 1/4 30 Sec 21 N/S 63 E Latitude 36° 05' 14.44" N UTM E NAD 27
PERMIT/WAIVER NO. MO-3051 160-30-000-003 Longitude 114° 59' 21.64" W UTM N NAD 83/WGS 84
Issued by Water Resources Current Parcel No

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor Auger Rotary RVC
 Mining / Dewater Corn / Ind Stock Air Mud Sonic
 Test / Other Mun / QM Rec Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
<u>Sand w Gravel and Silt</u>			<u>0'</u>	<u>20'</u>
<u>Silt w Sand and Clay</u>			<u>20'</u>	<u>30'</u>
<u>Sand w Gravel and Silt</u>			<u>30'</u>	<u>35'</u>
<u>Gravel w Silt</u>			<u>35'</u>	<u>40'</u>
<u>Silt w Clay</u>			<u>40'</u>	<u>50'</u>

9. INSTRUCTION
Depth Drilled: 50 Feet Depth Cased: 50 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>6.75</u> inches	<u>0</u> Feet
	<u>50</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.68</u>	<u>0.154</u>	<u>0</u>	

DCNR/DWR/SNRC
RECEIVED
MAY 21 2015

ANNULAR MATERIALS

Sanitary Seal Yes No

Neat Cement 0 to 38 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips 38 to 40 Pumped Poured
 Gravel Pack [> 0.2 in.] _____ to _____ Pumped Poured
 Sand Pack [< 0.2 in.] 38 to 50 Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

PERFORATIONS:

Type of perforation: Factory
Size of perforation: 0.02

From 40 Feet To 50 Feet
 From _____ Feet To _____ Feet
 From _____ Feet To _____ Feet
 From _____ Feet To _____ Feet

Date started: 4/21 2015
Date completed: 4/21 2015

7. WATER QUALITIES

Static water level: 18 Feet below land surface
 Artesian Flow: NA G.P.M. P.S.I.
 Water Temperature: NA ° Fahrenheit
 Water Quality: Clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision. This report is true to the best of my knowledge.

Name National EWP Contractor
 Address 5241 Schirls St. Las Vegas, NV 89118 Contractor

8. WELL TEST DATA

Test Method:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
G.P.M.			
Draw Down (Feet Below Static)			
Recorded Time (Hours)			

Nevada contractor's license number as issued by the State Contractor's Board: 0075355
 Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2512-LTD

Signed: Bob J
By driller performing actual work on site or contractor
 Date: 5/20/15

36.0873691
714.9885167
NAD 27