

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123252
Permit No. _____
Basin No. _____

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37837
WELL NAME (If applicable): PC-186-D

1. OWNER/CLIENT NAME Nevada Environmental Response Trust
MAILING ADDRESS 35 E Wacker DR. # 1550
Chicago IL 60601-2314

DETAILED ADDRESS AT WELL LOCATION 560 W. Lake Mead Parkway
Henderson, NV
Subdivision Name _____ County Clark

2. PLS LOCATION SW ¼ SE ¼ 12 Sec 22 N/S 62 E
PERMIT/WAIVER NO. MO-3004 178-12-801-008
Issued by Water Resources Current Parcel No.

Latitude 36° 02' 39.94" N UTM E NAD 27
Longitude 114° 59' 54.54" W UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Monitor
 Mining / Dewater Stock
 Test / Other Rec
 Irrigation Com / Ind
 Mun / QM

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Fill			0	2
Silty Sand			2	63
Silt			63	84
Sandy Silt			84	137
Clayey Silt			137	143
Silty Sand			143	144
Sandy Silt			144	147
Silt			147	152
Sandy Calyey			152	163
Silty Sand			163	165
Clayey Silt			165	170

9. INSTRUCTION
Depth Drilled: 170 Feet Depth Cased: 170 Feet
HOLE DIAMETER (BIT SIZE)
From To
8 Inches 0 Feet 170 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.500	2.01	0.237	0	170

ANNULAR MATERIALS
Sanitary Seal Yes No
 Neat Cement 0 to 144 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips 144 to 147 Pumped Poured
 Gravel Pack [> 0.2 in.] _____ to _____ Pumped Poured
 Sand Pack [< 0.2 in.] 147 to 170 Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

Date started: 10-Dec 2014
Date completed: 12-Dec 2014

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.01
From 150 Feet To 170 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

7. WATER QUALITIES
Static water level: 152 Feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP Contractor
Address 5241 Schirls St. Las Vegas, NV 89118 Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2512-LTD
Signed: Bob [Signature]
By driller performing regular drilling on site or contractor
Date: 2/9/2015

8. WELL TEST DATA

Test Method:	Bailer	Pump	Air Lift	Recorded Time (Hours)
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

36,044,427
- 115,993,433
NAD
27