STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123263
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 37850
WELL NAME (If applicable): INJ-1

1. OWNER/CLIENT NAME: Jose Rios - & Eleven Inc
MAILING ADDRESS: PO Box 7-11 Dallas TX 75221

DETAILED ADDRESS AT WELL LOCATION: 2003 N. Jones Blvd
Las Vegas, NV
Subdivision Name: County: Clark

2. PLS LOCATION: SW ¼ NW ¼ 24 Sec 20 N/S 60 E
PERMIT/WAIVER NO.: MO-3029 (Issued by Water Resources) 138-24-215-006 (Current Parcel No.)

Latitude: 36* 11' 45.80" N UTM E: ☒ NAD 27
Longitude: 115* 13' 25.04" W UTM N: ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

| Material Encountered | Lost Circ. | Water Strata | From | To |
|---|---|---|---|---|
| Asphalt | | | 0 | -5 |
| Silty Sands,coarse sand | | | .50 | |
| some cobles, | | | | 40 |
| Silt | | | 40 | 45 |
| Lean Clay with Sand | | | 45 | 48 |

Date started: 13-Mar, 20 15
Date completed: 13-Mar, 20 15

7. WATER QUALITIES
Static water level: 37.5 Feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☒ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Recorded Time (Hours) |
|---|---|---|
| | | |

9. CONSTRUCTION
Depth Drilled: 48 Feet Depth Cased: 48 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 8.25 | Inches | 0 | Feet | 48 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.375 | 0.68 | 0.154 | 0 | 48 |

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

| | | | | | |
|---|---|---|---|---|---|
| ☒ Neat Cement | | to | | ☐ Pumped | ☐ Poured |
| ☒ Cement Grout | 0 | to | 41 | ☒ Pumped | ☐ Poured |
| ☐ Concrete Grout | | to | | ☐ Pumped | ☐ Poured |
| ☒ Bentonite Chips | 41 | to | 43 | ☐ Pumped | ☒ Poured |
| ☐ Gravel Pack [ > 0.2 in. ] | | to | | ☐ Pumped | ☐ Poured |
| ☒ Sand Pack [ < 0.2 in. ] | 43 | to | 48 | ☐ Pumped | ☒ Poured |
| ☐ Other, explain: | | to | | ☐ Pumped | ☐ Poured |

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02

| From | Feet | To | Feet |
|---|---|---|---|
| 45 | | 48 | |
| | | | |
| | | | |
| | | | |
| | | | |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: National EWP (Contractor)
Address: 5241 Schirlls St. Las Vegas, NV 89118 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2512-LTD
Signed: Bob Zo (By driller performing actual drilling on site or contractor)
Date: 4/15/2015

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

DCNR/DWR/SNBO
RECEIVED
APR 16 2015

36.196056
-115.22362
NAD 27