STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123290
Permit No. 80698
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37303

1. OWNER STEVE MORRIS & KRISTINA PICKERING
MAILING ADDRESS 2508 PINTO LN
LAS VEGAS NV 89017-4626

ADDRESS AT WELL LOCATION 2508 PINTO LN
Las Vegas
Subdivision Name: County: Clark

2. LOCATION NW ¼ SE ¼ Sec 32 T 20S N or S R 61 E
PERMIT/WAIVER No. 80698 (Issued by Water Resources) 139-32-702-007 (Parcel No.)
Latitude N36°09'52.2" Longitude W115°10'33.7"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☒ Municipal/Industrial QM ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	3	-3
SANDY CLAY		3	85	-82
SMALL GRAVEL	WB	85	90	-5
CALICHIE		90	95	-5
CLAY & GRAVEL	WB	95	290	-195
LOOSE GRAVEL	WB	290	300	-10

DCNR/DWR/SNBI RECEIVED AUG 17 2015

Date started: 9-Jul, 20 15
Date completed: 16-Jul, 20 15

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12-1/4	Inches	0	Feet	53	Feet
7-7/8	Inches	53	Feet	300	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	.188	0	53
4.5	2.37	.248	0	300

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 60 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 53 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 53 to 300 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 43 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address 1220 MANSE RD (Contractor)
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the [illegible] 1573
Signed (By driller performing actual drilling on site or contractor)
Date 7/27/2015

(Rev. 06-08)

USE ADDITIONAL SHEETS IF NECESSARY

36.16453
-115.1751932
NAD 27

SEP 28, 2015 BY DB