STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123334
Permit No.
Basin No. 048

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73690
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME WENDY MCCLURE-PORTER
MAILING ADDRESS 650 GREENCREST DR
SPRING CREEK, NV 89815

DETAILED ADDRESS AT WELL LOCATION 650 GREENCREST DR
Subdivision Name: SPECIAL LANDS *County:* ELKO

2. PLS LOCATION NW ¼ SW ¼ 16 Sec 33N N/S 57 E
PERMIT/WAIVER NO. 006-52E-023
Issued by Water Resources *Current Parcel No.*

Latitude UTM E 621528 [X] NAD 27
Longitude UTM N 4510861 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Deepen: Orig WL#
[ ] Replacement: Original well log #
[ ] Recondition: Original well log #

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Monitor
[ ] Mining / Dewater [ ] Com / Ind [ ] Stock
[ ] Test / Other [ ] Mun / QM [ ] Rec

5. WELL TYPE
[ ] Auger [X] Rotary [ ] RVC
[X] Air [ ] Mud [ ] Sonic
[ ] Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
ALLUVIUM			0	20
LIGHT BROWN CLAYS			20	50
DARK GREEN CLAYS			50	125
SAND & GRAVEL w/ LIGHT		XX	125	
BROWN CLAYS				140

NAD 27
40.741629
115.560652

Date started: 19-Aug , 20 15
Date completed. 21-Aug , 20 15

7. *WATER QUALITIES*
Static water level: 74 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 62 ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
AT 140'	25		2 HOURS
AT 120'	20		1 HOUR
AT 100'	15		1/2 HOUR
AT 90'	5		1/2 HOUR

9. CONSTRUCTION
Depth Drilled: 140 Feet Depth Cased: 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+1.5	140

ANNULAR MATERIALS
Sanitary Seal [X] Yes [ ] No

[X] Neat Cement	4 to 105	[X] Pumped	[ ] Poured
[ ] Cement Grout	to	[ ] Pumped	[ ] Poured
[ ] Concrete Grout	to	[ ] Pumped	[ ] Poured
[ ] Bentonite Chips	to	[ ] Pumped	[ ] Poured
[X] Gravel Pack [> 0.2 in.]	105 to 140	[ ] Pumped	[X] Poured
[ ] Sand Pack [< 0.2 in.]	to	[ ] Pumped	[ ] Poured
[ ] Other, explain:	to	[ ] Pumped	[ ] Poured

PERFORATIONS:
Type of perforation: PLASMA CUT
Size of perforation: 3/16" X 4" 6 ROWS

From	Feet	To	Feet
120		140	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name HACKWORTH DRILLING INC. (Contractor)
Address P.O. BOX 850, ELKO, NV 89803 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* 020588
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2329
Signed: *By driller performing actual drilling on site or contractor*
Date: 9/4/2015

RECEIVED 2015 SEP 14 PM 12:08 STATE ENGINEERS OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.