

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT**

**OFFICE USE ONLY**  
Log No. 123344  
Permit No. \_\_\_\_\_  
Basin No. 107

**PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 73127  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME ALTON ANKERS  
MAILING ADDRESS 671 MOTTVILLE LANE  
GARDNERVILLE, NV 89460

DETAILED ADDRESS AT WELL LOCATION 864 PLYMOTH DRIVE  
SMITH, NV 89443  
Subdivision Name: \_\_\_\_\_ County: Lyon

2. PLS LOCATION NE 1/4 SW 1/4 17 Sec 11 N/S 24 E  
PERMIT/WAIVER NO. \_\_\_\_\_ 010-441-31  
*Issued by Water Resources Current Parcel No.*

Latitude 38.81845°N UTM E \_\_\_\_\_  NAD 27  
Longitude 119.320595°W UTM N \_\_\_\_\_  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  
 Mining / Dewater  
 Test / Other  
 Irrigation  
 Com / Ind  
 Mun / QM  
 Monitor  
 Stock  
 Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
BROWN CLAY			3	65
DG SANDS			65	135
GRAY SILTY CLAY			135	196
DG SILTY SANDS		X	196	200
DG SANDS AND SMALL SANDS		XXX	200	250

*NAD 27  
38.815537°N  
119.319603°W*

RECEIVED  
2015 SEP 11 AM 11:14  
STATE ENGINEERS OFFICE

Date started: 18-Aug , 20 15  
Date completed: 20-Aug , 20 15

9. INSTRUCTION

Depth Drilled: 250' Feet Depth Cased: 250' Feet

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
<u>11</u> inches	<u>0</u> inches	<u>250</u> Feet	<u>250</u> Feet
_____ inches	_____ inches	_____ Feet	_____ Feet
_____ inches	_____ inches	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/FL (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>+2</u>	<u>20</u>
<u>6 5/8</u>	<u>4.26</u>	<u>.216</u>	<u>20</u>	<u>250</u>
<u>SDR 21</u>				

ANNULAR MATERIALS

Sanitary Seal  Yes  No

Neat Cement to \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Cement Grout 0 to 100  Pumped  Poured

Concrete Grout to \_\_\_\_\_  Pumped  Poured

Bentonite Chips to \_\_\_\_\_  Pumped  Poured

Gravel Pack [ > 0.2 in. ] 100 to 250  Pumped  Poured

Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

PERFORATIONS:

Type of perforation: FACTORY MILL SLOT SAW CUT

Size of perforation: 0.032

From 220 Feet To 250 Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

7. WATER QUALITIES

Static water level: 95 Feet below land surface

Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water Temperature: 49' ° Fahrenheit

Water Quality: GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision. This report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.  
Contractor

Address 20 KIT KAT DRIVE CARSON CITY, NV 8706  
Contractor

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30+</u>	<u>65</u>	<u>3 HOURS</u>

Nevada contractor's license number as issued by the State Contractor's Board: 0055548

Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905

Signed: [Signature]  
By driller performing actual drilling on site or contractor

Date: 9/2/2015