STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123360
Permit No. 11241
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70003

1. OWNER VICTORY OUTREACH LAS VEGAS
MAILING ADDRESS PO BOX 42176
LAS VEGAS NV 89116

ADDRESS AT WELL LOCATION 540 N 28th
LAS VEGAS
Subdivision Name: County: CLARK

2. LOCATION NE ¼ NW ¼ Sec 36 T 20S N/S R 61 E
PERMIT/WAIVER No. 11241 139-36-110-034
Issued by Water Resources Parcel No.

Latitude N36°10'14.8" UTM E ☐ NAD 27
Longitude W115°06'40.3" N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	10	-10
RED CLAY & SAND		10	95	-85
WHITE CLAY & SAND		95	165	-70
RED CLAY/ SAND/ GRAVEL		165	260	-95
FINE SAND	WB	260	262	-2
CLAY & SAND	WB	262	335	-73
CEMENTED SAND & CLAY	WB	335	435	-100
LIME		435	440	-5

DCNR/DWR/SNBO
RECEIVED
MAY 08 2015

Date started: 27-Apr , 20 15
Date completed: 1-May , 20 15

9. WELL CONSTRUCTION
Depth Drilled 440 Feet Depth Cased 440 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12-1/4	Inches	0	Feet	99	Feet
7-7/8	Inches	99	Feet	440	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	.188	+2	99
4.5	2.37	.248	0	440

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 340 feet to 440 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 99 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 6 to 440 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: ARTESIAN feet below land surface
Artesian Flow: 4 G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address 1220 MANSE RD (Contractor)
PAHRUMP NV 89048
Nevada contractor's license number issued by the *State Contractor's Board* 47333
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2513
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5/4/2015

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36.1708067
-115.1103609
NAD 27