WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 123371
Permit No.
Basin

NOTICE OF INTENT NO. 33127

1. OWNER Paula D. Lynch
MAILING ADDRESS P.O. Box 864
Mercury, NV 89023-0864

ADDRESS AT WELL LOCATION
1020 E. Fremont 36D7' 43.65"N 115D 59'33.73"W

2. LOCATION N/W 1/4 N/W 1/4 Sec. 14 T 21S N/S R 53E E Nye County
PERMIT NO. Issued by Water Resources
44-702-09 Parcel No.
Mesa Oeste Estates Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
unknown		0	140	140
See next line	x	140	250	140
brown loam with caleche strings				
gravel	x	250	252	110
See next line	x	252	270	12
brown loam with caleche strings				

DCNR/DWR/SNRC
RECEIVED
MAR 2 6 2015

Date started 2/22/1915 2015, 19__
Date completed 2/22/1915, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7.5 Inches		140 Feet	270 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	270

Perforations:
Type perforation sawcut
Size perforation .188
From 190 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 132 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 5801 S. Homestead Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Laura Strickland
By driller performing actual drilling on-site or contractor
Date 3.17.15

36.1288287
-115.9918454
NAD 27