

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123403
Permit No. _____
Basin No. _____

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37866
WELL NAME (If applicable): BH-1

1. OWNER/CLIENT NAME Brad Rambo/Springmountain Raceway
MAILING ADDRESS 3601 S Hwy 160 Pahrump, NV, 89047

DETAILED ADDRESS AT WELL LOCATION 3601 S Hwy 160
Pahrump, NV, 89047

Subdivision Name _____ County Nye

2. PLS LOCATION SW ¼ NE ¼ 33 Sec 20 N/S 54 E
PERMIT/WAIVER NO. MO-3070 027-741-16
Issued by Water Resources Current Parcel No.

Latitude 36°10'17.41"N UTM E NAD 27
Longitude 115°54'41.26"W UTM N _____ NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG				
Material Encountered	Lost Circ.	Water Strata	From	To
Gravel with silt and sand/dense sandstone and siltstone			0	50
Well graded sand with silt and gravel very dense and damp.			50	60
few cobbles and thin layer of caliche.				
Well graded sand with silt and very dense, with cobbles and damp.		67	60	70
Well graded gravel with silt and sand, very dense, saturated.			70	80
Sandy lean clay with sand and gravel, very stiff to hard, moist.			80	90
Silty sand with gravel very dense moist.			90	100
Sandy lean clay hard, moist			100	110
Sandy silt, hard, moist, trace of fine gravels.			110	130
Sandy lean clay, very stiff, moist, trace of fine gravels.			130	140
Sandy lean clay, very stiff, moist, fine to medium sand.			140	150

9. INSTRUCTION
Depth Drilled: 150 Feet Depth Cased: 150 Feet

HOLE DIAMETER (BIT SIZE)				
	From	To		
	<u>8</u> Inches	<u>0</u> Feet	<u>150</u> Feet	

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.68</u>	<u>0.154</u>	<u>0</u>	<u>80</u>

ANNULAR MATERIALS
Sanitary Seal Yes No
 Neat Cement 0 to 56 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips 56 to 58 Pumped Poured
 Gravel Pack [> 0.2 in.] _____ to _____ Pumped Poured
 Sand Pack [< 0.2 in.] 58 to 80 Pumped Poured
 Other, explain: _____ Pumped Poured
Bentonite chips from 80 to 150 feet

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02
From 60 Feet To 80 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

Date started: 10-Jun, 20 15
Date completed: 10-Jun, 20 15

7. WATER QUALITIES
Static water level: 67 Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ ° Fahrenheit
Water Quality: _____

8. WELL TEST DATA

Test Method:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP Contractor
Address 5241 Schirls St. Las Vegas, NV, 89118 Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2512-LTD
Signed: Bob [Signature]
By driller performing well drilling on site or contractor
Date: 6/25/15

36.1715402 NAD
- 115.9106048 27