

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123410
Permit No. _____
Basin No. _____

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37859
WELL NAME (if applicable): MW-23

1. OWNER/CLIENT NAME Ace Cab LLC dba Ace Cab Phys Frms
MAILING ADDRESS 5015 Valley View Blvd Las Vegas, NV 89118
DETAILED ADDRESS AT WELL LOCATION 5015 Valley View Blvd Las Vegas, NV 89118
Subdivision Name: _____ County Clark
2. PLS LOCATION NW 1/4 NW 29 Sec 21 T16 S 61 E Latitude 36°05'53.97"N UTM E NAD 27
PERMIT/WAIVER NO. MO-3057 162-29-111-001 Longitude 115°11'20.51"W UTM N NAD 83/WGS 84
Issued By Water Resources Current Parcel No.

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____
4. PROPOSED USE
 Domestic Irrigation Monitor Auger Rotary RVC
 Mining / Dewater Com / Ind Stock Air Mud Sonic
 Test / Other Mun / QM Rec Other _____

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
<u>Lt Brown Gravelly Caliche</u>			<u>0</u>	<u>5</u>
<u>Very Rocky Lt. Brown Sand</u>				
<u>Lt Brown Sand w/ some silt and Caliche</u>			<u>5</u>	<u>10</u>
<u>tan Gravelly Silt</u>			<u>10</u>	<u>20</u>
<u>Brown Silt w/ trace Gravels</u>			<u>20</u>	<u>25</u>
<u>Brown lean clay w/ trace Gravels</u>			<u>25</u>	<u>30</u>
<u>Brown Silty Gravel</u>			<u>30</u>	<u>35</u>
<u>Brown Gravel Silt w/ trace Sand</u>			<u>35</u>	<u>40</u>

9. INSTRUCTION
Depth Drilled: 40 Feet Depth Cased: 40 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 40 Feet
8.25 Inches _____ Feet _____
Inches _____ Feet _____
Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.68</u>	<u>0.154</u>	<u>0</u>	<u>25</u>

ANNULAR MATERIALS
Sanitary Seal Yes No
 Neat Cement 0 to 21 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips 21 to 23 Pumped Poured
 Gravel Pack [> 0.2 in.] _____ to _____ Pumped Poured
 Sand Pack [< 0.2 in.] 23 to 40 Pumped Poured
 Other, explain: _____ Pumped Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02
From 25 Feet To 40 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

Date started: 5-4-15 20 15
Date completed: 5-4-15 20 15

7. WATER QUALITIES
Static water level: 27.5 Feet below land surface
Artesian Flow: NA G.P.M. _____ P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP Contractor
Address 5241 Schirlls St. Las Vegas, NV 89118 Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2512-LTD
Signed: Bob M
Date: 5/29/15
By driller performing actual drilling on site or contractor

36,098325 NAD
-115,1890305 29