STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123412
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37859
WELL NAME (If applicable): MW-25

1. OWNER/CLIENT NAME Ac•Cab LLC dba ACE Cab, Phyllis Frias
MAILING ADDRESS 5010 S. Valley View blvd, Las Vegas NV-89118

DETAILED ADDRESS AT WELL LOCATION 5010 S. Valley View blvd Las Vegas, NV, 89118
Subdivision Name: County: Clark

2. PLS LOCATION NW ¼ NW ¼ 29 Sec 21 N/S 61 E
PERMIT/WAIVER NO. MO-3057 (Issued by Water Resources) 162-29-111-001 (Current Parcel No.)

Latitude 36°05'54.96" N UTM E ☑ NAD 27
Longitude 115°11'20.13" W UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☑ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Concrete, asphalt, Tire			0	5
Gravel, Sand, asphaltic Material				
Beige, Silty gravel with Some Sand			5	10
Beige Sandy Silt w/ black gravel, gray Staining			10	15
Tan Gravely Silt			15	20
Lt. Brown Sandy Silt			20	25
Brown lean clay w/Trace Gravel			25	30
Caliche, Brown gravely lean clay			30	35
Gray Silty gravel			35	40

DCNR/DWR/SNBC
RECEIVED
MAY 29 2015

Date started: ~~3+~~ 5-5-15, 20 15
Date completed: 5-5-15, 20 15

7. WATER QUALITIES
Static water level: 31 Feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: 40 Feet Depth Cased: 40 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.25	Inches	0	Feet	40	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.68	0.154	0	25

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

☑ Neat Cement	0 to 21	☑ Pumped	☐ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☑ Bentonite Chips	21 to 23	☐ Pumped	☑ Poured
☐ Gravel Pack [> 0.2 in.]	to	☐ Pumped	☐ Poured
☑ Sand Pack [< 0.2 in.]	23 to 40	☐ Pumped	☑ Poured
☐ Other, explain:	to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02
From 25 Feet To 40 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP (Contractor)
Address 5241 Schirlls St. Las Vegas, NV 89118 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2512-LTD
Signed: Bob N (By driller performing actual drilling on site or contractor)
Date: 5-29-15

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.09860
-115.188925
NAD 27