STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123418
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37866
WELL NAME *(if applicable)*: BH-1

1. OWNER/CLIENT NAME Brad Rambo Spring Mt Raceway
MAILING ADDRESS 3601 S Hwy 160
Pahrump, NV 89048

DETAILED ADDRESS AT WELL LOCATION 3601 S Hwy 160
Pahrump, NV 89048
Subdivision Name: *County:* Clark

2. PLS LOCATION sw ¼ ne ¼ 33 Sec 20 N/S 54 E
PERMIT/WAIVER NO. M/O 3070 *Issued by Water Resources* 027-741-16 *Current Parcel No.*

Latitude 36 10 17.41 UTM E ☐ NAD 27
Longitude -115 54 41.26 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
sand, gravel, rocks			0	60
sand smal gravel			60	80
tan clay			80	150
Well sampled, then removed and plugged				

DCNR/DWR/SNBO RECEIVED JUL 15 2015

Date started: 10-Jun , 20 15
Date completed: 10-Jun , 20 15

7. *WATER QUALITIES*
Static water level: 67 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality: good

8. WELL TEST DATA
Test Method: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: 150 Feet Depth Cased: 80 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	150	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.5	0.68	PVC sch 40 .154	0	80

ANNULAR MATERIALS
Sanitary Seal ☐ Yes x ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	53	to	58	☐ Pumped	☐ x Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	58	to	80	☐ Pumped	☐ x Poured
☒ Other, explain:	80	to	150	☐ Pumped	☐ x Poured

PERFORATIONS:
Type of perforation: slots
Size of perforation: 0.02

From 60	Feet	To 80	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP *Contractor*
Address 580 W Silver St Elko, NV 89801 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 76355
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2420
Signed: Neil Slade *By driller performing actual drilling on site or contractor*
Date: 6/26/2015

RECEIVED 2015 JUL 13 AM 8:30 WATER ENGINEERS OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.1715402 NAD
-115.9106048 27