STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123429
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37865
WELL NAME *(if applicable)*: MW26D

1. OWNER/CLIENT NAME Paul Roberts Upland Square
MAILING ADDRESS 6450 Spring Mt Rd #2
Las Vegas, NV 89146

DETAILED ADDRESS AT WELL LOCATION 5636 W Charleston Blvd
Las Vegas, NV 89146
Subdivision Name: *County:* Clark

2. PLS LOCATION SE ¼ SW ¼ 36 Sec 20 N/S 60 E
PERMIT/WAIVER NO. M/O 3062 *Issued by Water Resources* 138-36-408-002 *Current Parcel No.*

Latitude 36.159443 UTM E ☐ NAD 27
Longitude -115.218457 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
sand		no	0	2
caliche			2	4
silty clay			4	25
gravel 3/4"			25	35
sandy gravel		no	35	55
clay with sand		yes	55	110

DCNR/DWR/SNBC
RECEIVED
JUL 15 2015

Date started: 8-Jun , 20 15
Date completed: 9-Jun , 20 15

9. CONSTRUCTION
Depth Drilled: 110 Feet Depth Cased: 110 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	110	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.11	.237	0	110

ANNULAR MATERIALS

Sanitary Seal x ☐ Yes ☐ No

☒ Neat Cement	0	to	100	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	100	to	103	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	103	to	110	☐ Pumped	☒ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:

Type of perforation: slots
Size of perforation: 0.02

From	Feet	To	Feet
105	Feet	110	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. *WATER QUALITIES*
Static water level: 70 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality: good

8. WELL TEST DATA
Test Method: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP *Contractor*
Address 580 W Silver St Elko, NV 89801 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board*: 75355
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 2420
Signed: Neil Hale *By driller performing actual drilling on site or contractor*
Date: 6/26/2015

RECEIVED JUL 13 2015 NEVADA ENGINEERS OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.1594736
-115.2176217
NAD 27