STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123436
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34196
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME City of Las Vegas
MAILING ADDRESS 332 N Rancho 8th Floor

DETAILED ADDRESS AT WELL LOCATION 9300 ALTA DR
LAS VEGAS,NV
Subdivision Name. *County:* Clark

2. PLS LOCATION NE ¼ NE ¼ 31 Sec 20S N/S 60 E
PERMIT/WAIVER NO. R-012 *Issued by Water Resources* | 13831501003 *Current Parcel No.*

Latitude | UTM E 653023.4824 ☐ NAD 27
Longitude | UTM N 4004154.064 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☒ Recondition: Original well log # 59759

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☒ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
EXTEND CASING TO 20"				
ABOVE LAND SURFACE				
WELDED TOP PLATE W/				
1.5" & 4" ACCESE PORTS				
WELL IS PART OF THE				
LAS VEGAS VALLEY GROUND				
WATER MANAGEMENT PROGRAM				

DCNR/DWR/SNBO
RECEIVED
JUN 16 2015

Date started: 9-Jun , 20 15
Date completed: 9-Jun , 20 15

7. WATER QUALITIES
Static water level: Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. INSTRUCTION
Depth Drilled: 1010 Feet Depth Cased: 1000 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
30"	Inches	0	Feet	55	Feet
22"	Inches	55	Feet	1010	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14"		.375	0	1000
24"		.375	0	55

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 55	☒ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: ROSCOE MOSS FULL FLOW
Size of perforation: 0.156

From	Feet	To	Feet
620	Feet	980	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name LVVWD *Contractor*
Address 1001 VALLEY VIEW ,LAS VEGAS ,NV. *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* N/A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)* 1594
Signed: *By driller performing actual drilling on site or contractor*
Date: 6/16/2015

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.

36.1701098
-115.2977246
NAD 27