STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123440
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37817
WELL NAME (If applicable): MW-1

1. OWNER/CLIENT NAME: Resolute Commercial Services
MAILING ADDRESS: 7201 E. Camelback Rd., Suite 250
Scottsdale, AZ 85251

DETAILED ADDRESS AT WELL LOCATION: 4375 Las Vegas Blvd
North Las Vegas
Subdivision Name: County: Clark

2. PLS LOCATION: NE ¼ SW ¼ 4 Sec 20 N/S 62 E
PERMIT/WAIVER NO.: MO-3047 (Issued by Water Resources) 140-04-301-007 (Current Parcel No.)

Latitude: 36* 14' 22.80" N UTM E:
Longitude: 115* 03' 25.45" W UTM N:
☑ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☑ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt			0	-3
Class II Base			-3	-9
Clayey gravel w/sand			-9	5
Sandy clay trace of gravel			5	13
Clayey gravel w/sand			13	18
Sandy clay trace of gravel			18	23
Clachie,gravel			23	30
Clayey sand			30	35
Sandy clay			35	45
Clayey Sand			45	60

DCNR/DWR/SNBC
RECEIVED
MAY 08 2015

Date started: 15-Apr, 20 15
Date completed: 15-Apr, 20 15

7. WATER QUALITIES
Static water level: 45 Feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: 60 Feet Depth Cased: 60 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.25	Inches	0	Feet	60	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.68	0.154	0	60

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

☑ Neat Cement	0	to 35	☑ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☑ Bentonite Chips	35	to 38	☐ Pumped	☑ Poured
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☑ Sand Pack [< 0.2 in.]	38	to 60	☐ Pumped	☑ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02

From	Feet	To	Feet
40		60	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: National EWP (Contractor)
Address: 5241 Schirlls St. Las Vegas, NV 89118 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2512-LTD
Signed: Bob M (By driller performing actual drilling on site or contractor)
Date: 5/7/15

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.239667
-115.0570694
NAD 27