

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 123457  
Permit No. \_\_\_\_\_  
Basin No. 106

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73960  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME Ron Hastic  
MAILING ADDRESS PO 324 Bishop CA 93515

DETAILED ADDRESS AT WELL LOCATION 419 Grass Hills Wellington, NV 89444

2. PLS LOCATION N 1/4 SE 1/4 11 Sec 10 N/S 32 E  
PERMIT/WAIVER NO. 1002-11-002-002  
Issued by Water Resources Current Parcel No.

Subdivision Name: \_\_\_\_\_ County: Douglas  
Latitude 37 44.587 UTM E  NAD 27  
Longitude 119 20.797 UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Com / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Dirt + Cobbles			0	15	15
Gravel			15	78	63
Sand + Clay			78	84	6
Cobbles + Gravel			84	210	126
Fractured Rock			210	304	94
Brown Clay			304	312	8
Multi Colored Chip Rock			312	400	88

9. WELL CONSTRUCTION

Depth Drilled: 400 Feet  
Depth Cased: 400 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>11</u>	<u>0</u>	<u>75</u>
<u>9 7/8</u>	<u>75</u>	<u>400</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>20</u>
<u>6 5/8</u>		<u>SDR 21</u>	<u>20</u>	<u>400</u>

PERFORATIONS:

Type of perforation: Factory Cut  
Size of perforation: 31/32

From 400 Feet To 380 Feet  
From 360 Feet To 340 Feet  
From 320 Feet To 300 Feet

ANNULAR MATERIALS

Sanitary Seal 0 to 58  
 Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Cement Grout 0 to 58  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Chips \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

15%  20%  Other, explain: \_\_\_\_\_

Gravel Pack [ > 0.2 in. ] 58 to 400  Pumped  Poured  
 Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Date started: 8-21-15, 20  
Date completed: 8-23-15, 20

7. WATER QUALITIES  
Static water level: 135 Feet below land surface  
Artesian Flow: No G.P.M. 40+ P.S.I.  
Water Temperature: 61 ° Fahrenheit  
Water Quality: Clear

8. WELL TEST DATA

Test Method:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<u>40+</u>		<u>3.5</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision. This report is true to the best of my knowledge.

Name: \_\_\_\_\_  
Address: BLAIN DRILLING & PUMPING  
P.O. Box 1255  
Carson City, NV 89702

Nevada contractor's license number as issued by the State Contractor's Board: 46497A  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2514

Signed: Bob Gollins  
By driller performing actual drilling on site or contractor  
Date: 9-10-15

RECEIVED  
2015 SEP 18 PM 4:19  
STATE ENGINEERS OFFICE

NAD 27  
38.743209  
119.478967