

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123460
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37299

1. OWNER SHARLENE URG ADDRESS AT WELL LOCATION 8091 S RALPH CT
MAILING ADDRESS 8091 S RALPH CT PAHRUMP
PAHRUMP NV 89061-9027 Subdivision Name: _____ County: NYE

2. LOCATION NW 1/4 NW 1/4 Sec 28 T 21S N/S R 54 E Latitude N36°06'05.9" UTM E NAD 27
PERMIT/WAIVER No. 45-371-31 Longitude W115°55'05.4" N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock Air Other

5. WELL TYPE
 Cable Rotary RVC
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|-------------------|--------------|------|-----|-----------|
| ROCK & SANDY LOAM | | 0 | 15 | -15 |
| CLAY & SAND | | 15 | 55 | -40 |
| CALICHIE | WB | 55 | 65 | -10 |
| CLAY | | 65 | 105 | -40 |
| SANDSTONE | WB | 105 | 110 | -5 |
| CLAY & GRAVEL | | 110 | 150 | -40 |
| CALICHIE | WB | 150 | 170 | -20 |
| CLAY & GRAVEL | | 170 | 190 | -20 |
| GRAVEL & CALICHIE | WB | 190 | 200 | -10 |

DCNR/DWR/SNBO RECEIVED
JUN 29 2015

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 200
Inches Feet Feet Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 4.5 | 2.37 | .248 | 0 | 200 |
| 6 | 10.78 | .250 | +2 | 8 |

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 160 feet to 200 feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement 0 to 95 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured
Gravel Pack: Yes No 95 to 200 Pumped Poured
Type: _____
Bentonite Chips: Yes No _____ to _____ Pumped Poured
Type: _____

7. Water Level
Static water level: ARTESIAN feet below land surface
Artesian Flow: 3 G.P.M. MINUTE P.S.I.
Water Temperature: 64 °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING Contractor
Address 1220 MANSE RD Contractor
PAHRUMP NV 89048
Nevada contractor's license number 47333
issued by the State Contractor's Board
Nevada driller's license number issued by the 2513
Division of Water Resources, the on-site driller
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 6/22/2015