STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123467
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37884
WELL NAME (*if applicable*): AS-12D

1. OWNER/CLIENT NAME: Jose Rios, 7-eleven Inc
MAILING ADDRESS: P.O. Box 711 Dallas,Tx,75221

DETAILED ADDRESS AT WELL LOCATION: 2725 North Las Vegas BLVD
North Las Vegas,NV,89030
Subdivision Name:
County: Clark

2. PLS LOCATION: NE ¼ SW ¼ 13 Sec 20 N(S) 61 E
PERMIT/WAIVER NO: m0-3088 (Issued by Water Resources)
139-13-303-006 (Current Parcel No.)

Latitude: 36.209350"N
Longitude: 115.108328"W
UTM E:
UTM N:
☐ NAD 27
☑ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☑ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☑ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt			0	3"
Sandy silt,wet at 35'			3"	40
Elastic silt ,stained, wet			40	50
Silty sand and wet			50	55
Silty sand soft ,strong odor,wet			55	60
Elsatic silt , odor and stained,			60	67
firm and moist with some gravel				

DCNR/DWR/SNBO
RECEIVED
SEP 17 2015

Date started: 24-Aug , 20 15
Date completed: 24-Aug , 20 15

7. WATER QUALITIES
Static water level: 37' Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
1.5	0	1

9. INSTRUCTION
Depth Drilled: 67 Feet Depth Cased: 67 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.25	Inches	0	Feet	67	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.68	0.154	0	67

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☑ Cement Grout	0	to	58	☑ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☑ Bentonite Chips	58	to	63	☐ Pumped	☑ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☑ Sand Pack [< 0.2 in.]	63	to	67	☐ Pumped	☑ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS.
Type of perforation: Stainless Steel
Size of perforation: 20

From	Feet	To	Feet
65	Feet	67	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: National EWP (Contractor)
Address: 4221 W. Oquendo Rd, Las Vegas, NV, 89118 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board*: 0075355
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 2526
Signed: (by driller performing actual drilling on site or contractor)
Date: 9/16/2015

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.2093793
-115.1074932
NAD 27