

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123584
Permit No. 48328
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73717

1. OWNER Newmont Mining Corp ADDRESS AT WELL LOCATION Gold Quarry
MAILING ADDRESS 1655 Mountain City Hwy Carlin NV
Elko NV. 89801 Subdivision Name: _____ County: Eureka

2. LOCATION SE 1/4 SE 1/4 Sec 6 T 33 N3R 52 E Latitude 40°46.09975' N UTM E NAD 27
PERMIT/WAIVER No. 48328 Longitude 116°09.76690' W N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|------|----|------------|
| <u>QPLW-00013</u> | | | | |
| <u>Abandoned bottom of well from 796' to 598' with neat cement.</u> | | | | |
| <u>Set new Liner from 590' to surface. Old gravel pack filled in bottom 8' while we set new liner.</u> | | | | |
| <u>Pour glass beads from surface to 590'</u> | | | | |
| <u>5" Thick steel plate welded to 12.75" Casing and 9.5" Liner at surface.</u> | | | | |
| <u>NAD 27</u> | | | | |
| <u>40.768413</u> | | | | |
| <u>116.161869</u> | | | | |

9. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased 590 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | Feet | Feet | Feet |
|--------|-------|-------|-------|
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-------------|
| <u>9.12"</u> | <u>29.7</u> | <u>1/4"</u> | <u>+1</u> | <u>-590</u> |

Perforations:

Type of perforation Full Flo Lower liner

Size of perforation 0.060 slot

From 590 feet to 470 feet
From 450 feet to 190 feet

Annular Seal: Yes No

Neat Cement 796' to 598' Pumped Poured
 Cement Grout _____ Pumped Poured
 Concrete Grout _____ Pumped Poured
 ≥30% Bentonite Grout _____ Pumped Poured

Gravel Pack: Yes No _____ Pumped Poured

Type: 2.0-2.4mm Sili beads (#450PR) (glass beads)

Bentonite Chips: Yes No _____ Pumped Poured

Type: _____

7. Water Level

Static water level: 123' feet below land surface

Artesian Flow: NO G.P.M. _____ P.S.I. _____

Water Temperature: 61.7 °F

Quality: Good

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the reports true to the best of my knowledge.

Name Boart Longyear Contractor

Address P.O. Box 2748 Contractor

Elko NV 89803

Nevada contractor's license number _____

issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2396

Signed Fermin Luna
By driller performing actual drilling on-site or contractor

Date 10-25-15

RECEIVED
OCT 25 10 PM 1:27
ENGINEERS OFFICE

Reconditioning well PW-13