PRW-7

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123603
Permit No.
Basin 064

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70110

1. OWNER Battle Mt. Truck Stop LLC
MAILING ADDRESS P.O. Box 14646
Spokane Valley WA. 99214

ADDRESS AT WELL LOCATION 1600 W. Front St.
Battle Mt. NV.
Subdivision Name: County: Lander

2. LOCATION ~~NE~~ ¼ ~~NE~~ ¼ Sec 18 T 32 ~~N~~ S R 45 E
PERMIT/WAIVER No. SW *Issued by Water Resources*
Parcel No. 02-260-09

Latitude 40.649969 N.
Longitude -116.945762
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND / SILT		0	5	5
SAND		5	10	5
SAND W/ GRAVEL		10	20	10

NAD 27
40.649998
116.948707

RECEIVED
2015 NOV 12 AM 11:22
DIVISION OF WATER RESOURCES

Date started: 10-13 , 20 15
Date completed: 10-13 , 20 15

7. Water Level
Static water level: 10 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	20 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		SCH-40	0	20

Perforations:
Type of perforation Manufactured
Size of perforation .020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☒ Neat Cement 0 to 3 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 4 to 20 ☐ Pumped ☒ Poured
Type: #3 SAND
Bentonite Chips: ☒ Yes ☐ No 3 to 4 ☐ Pumped ☐ Poured
Type: 3/8 bent. chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gregg Drilling & Testing Inc. (Contractor)
Address 950 Howe Rd Martinez CA 94553 (Contractor)

Nevada contractor's license number issued by the *State Contractor's Board* C23-0038113
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2328

Signed (By driller performing actual drilling on site or contractor)
Date 10-19-15

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY